


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 7230870**

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2021	May2022 Aug2022	Apr2023 Oct2023 Jan2024	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015354	KCPA008590	KCPA007231
Sample Date		Client Info		10 Apr 2024	10 Jan 2024	12 Oct 2023
Machine Age	hrs	Client Info		7488	6805	5983
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	<1
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	2	<1
Lead	ppm	ASTM D5185m	>10	0	1	<1
Copper	ppm	ASTM D5185m	>50	2	5	1
Tin	ppm	ASTM D5185m	>10	0	1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	5	<u>18</u>	0
Molybdenum	ppm	ASTM D5185m	0	0	1	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	19	47	43
Calcium	ppm	ASTM D5185m	0	0	2	2
Phosphorus	ppm	ASTM D5185m	0	<1	15	4
Zinc	ppm	ASTM D5185m	0	0	7	6
Sulfur	ppm	ASTM D5185m	23500	17667	21568	18779
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		9	0	10
Potassium	ppm	ASTM D5185m		0	2	2
Water	%	ASTM D6304	>0.05	0.010	△ 0.367	<b>△</b> 0.304
ppm Water	ppm	ASTM D6304	>500	102	▲ 3670	▲ 3040
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		13022		
Particles >6μm		ASTM D7647		<u>▲</u> 5836		
Particles >14µm		ASTM D7647	>80	<u>197</u>		
Particles >21µm		ASTM D7647	>20	<b>△</b> 36		
Particles >38μm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>21/20/15</u>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.37	0.38	0.33



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

: KCPA015354 Lab Number : 06149530 Unique Number : 10979608

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Apr 2024 **Tested** : 16 Apr 2024

Diagnosed : 17 Apr 2024 - Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - UPSSMY

**UPS** 

T:

F:

**423 LIBERATOR LN** 

Contact: Service Manager

SMYRNA, TN

US 37167