


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7858870

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121657	KC106819	KC107437
Sample Date		Client Info		08 Mar 2024	01 Dec 2023	30 Dec 2022
Machine Age	hrs	Client Info		5325	5148	4746
Oil Age	hrs	Client Info		0	223	1242
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	1	3	2
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m	-	0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	1-1-	method	limit/base	current	history1	history2
Boron		ASTM D5185m			0	0
	ppm	ASTM D5185m	90	0 3	3	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0		0
Manganese Magnesium	ppm	ASTM D5185m	90	65	<1 71	54
Calcium	ppm	ASTM D5185m		ەت <1	2	0
	ppm	ASTM D5185m	2	1	<1	2
Phosphorus	ppm	ASTM D5185m		ו <1	<1	13
Zinc	ppm	ASTIVI DOTIODITI		<1	0	13
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		18	17	18
Potassium	ppm	ASTM D5185m	>20	2	4	6
Water	%	ASTM D6304	>0.05	0.017	0.020	0.014
ppm Water	ppm	ASTM D6304	>500	173	201	147.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			23480	13664
Particles >6µm		ASTM D7647	>1300		<u> </u>	▲ 5224
Particles >14µm		ASTM D7647	>80		4 74	<u> </u>
Particles >21µm		ASTM D7647			<u> </u>	<u> </u>
Particles >38µm		ASTM D7647	>4		4	1 1
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		A 22/20/16	1/20/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.40	0.38	0.38



38 Aug6/21.

OIL ANALYSIS REPORT





un16/22

sc30/22


Mar21/22

Dec7/21


Dec1/23 -

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	A MODER	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.6	44.5	44.2
SAMPLE IMAGES		method	limit/base	current	history1	history2
						A DESCRIPTION OF THE OWNER

Color



Bottom



Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: POWCIN [WUSCAR] 06149532 (Generated: 04/17/2024 23:45:04) Rev: 1

Certificate 12367

Contact/Location: Service Manager - POWCIN

T:

F: