

### **PROBLEM SUMMARY**


Machine Id


# KAESER SFC 37T 6711651 (S/N 1102)

Component Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

### COMPONENT CONDITION SUMMARY





DIRT

### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

### PROBLEMATIC TEST RESULTS

FRODLEMATIC TEST RESULTS								
Sample Status				SEVERE	SEVERE	SEVERE		
Silicon	ppm	ASTM D5185m	>25	<b>1</b> 19	<b>A</b> 86	<b>a</b> 301		
Particles >6µm		ASTM D7647	>1300	<b>A</b> 3177				
Particles >14µm		ASTM D7647	>80	<u> </u>				
Particles >21µm		ASTM D7647	>20	<b>A</b> 330				
Particles >38µm		ASTM D7647	>4	<u> </u>				
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 20/19/17				

Sample Rating Trend

Customer Id: SILEAS Sample No.: KC112417 Lab Number: 06150348 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

DIRT	<b>29 Sep 2023 Diag: Don Baldridge</b> The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. We were unable to perform a particle count on this sample.All component wear rates are normal.
$\mathbf{\mathbf{S}}$	Elemental level of silicon (Si) above normal indicating ingress of dirt/seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Date

\_\_\_\_

### 13 Mar 2023 Diag: Jonathan Hester

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. Elemental level of silicon (Si) above normal indicating ingress of seal material. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for rates are normal. Elemental level of silicon (Si) above normal. There is a light concentration of water present in the

We advise that you check all areas where dirt can enter the system. There is too much water present in this this component. We recommend an early resample in 500 hours to monitor this condition.All component wear oil. Free water present. The AN level is acceptable for this fluid.

### 19 Sep 2022 Diag: Don Baldridge

DIRT

DIRT

**RECOMMENDED ACTIONS** 

HISTORICAL DIAGNOSIS

Status

\_\_\_\_

Action

Change Fluid

Change Filter

Resample

Done By

?

?

?

Oil and filter change at the time of sampling has been noted.

Oil and filter change at the time of sampling has been noted.

We recommend an early resample to monitor this condition.



view report







### **OIL ANALYSIS REPORT**

Sample Rating Trend

DIRT

X

### Machine Id KAESER SFC 37T 6711651 (S/N 1102)

Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

### DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC112417	KC124288	KC106109
Sample Date		Client Info		11 Mar 2024	29 Sep 2023	13 Mar 2023
Machine Age	hrs	Client Info		29455	27606	23159
Oil Age	hrs	Client Info		6326	0	6393
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				SEVERE	SEVERE	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	17	6
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	<1	<1
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	2	2
Zinc	ppm	ASTM D5185m		0	10	0
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>119</b>	<b>8</b> 6	<b>a</b> 301
Sodium	ppm	ASTM D5185m		2	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.05	0.006	0.009	0.007
ppm Water	ppm	ASTM D6304	>500	61	96.8	78.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7523		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	<mark>/</mark> 792		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	<b>4</b> 15		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 20/19/17		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.44	0.39	0.41





## **OIL ANALYSIS REPORT**














Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SILEAS [WUSCAR] 06150348 (Generated: 04/18/2024 15:02:55) Rev: 1

Contact/Location: Service Manager - SILEAS Page 4 of 4

F: