


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

7550917 (S/N 1367)

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121266	KC06000550	KC107789
Sample Date		Client Info		04 Apr 2024	30 Oct 2023	17 May 2023
Machine Age	hrs	Client Info		10133	8252	6966
Oil Age	hrs	Client Info		0	0	1430
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	4	12	5
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	32	0	8
Molybdenum	ppm	ASTM D5185m	50	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	50	19	46
Calcium	ppm	ASTM D5185m		0	0	2
Phosphorus	ppm	ASTM D5185m	2	0	2	<1
Zinc		ASTM D5185m		۰ <1	0	4
	ppm	ASTIVI DJIOJIII		<1 <1	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		16	6	9
Potassium	ppm	ASTM D5185m	>20	2	1	2
Water	%	ASTM D6304		0.014	0.010	0.031
ppm Water	ppm	ASTM D6304	>500	143	103.2	312.7
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		37963	5927	43127
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	1 7529
Particles >14µm		ASTM D7647	>80	<u> </u>	A 355	A 2155
Particles >21µm		ASTM D7647	>20	<u> </u>	<u> </u>	▲ 604
Particles >38µm		ASTM D7647	>4	2	4	A 23
Particles >71µm		ASTM D7647	>3	0	0	1
i al doloo y i i pili						
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	🔺 20/19/16	<u> </u>
	TION	ISO 4406 (c) method	>/17/13 limit/base	22/21/17	20/19/16 history1	23/21/18 history2

-COMPRESSOR Built for a lifetime

50

(Im 40

왕 30k

20

101 E

0


(J-0+) ts 44


47


3


B

Abnorma 40










Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.3	44.1	44.1
-	001					
SAMPLE IMAGES		method	limit/base	current	history1	history2
-		method	limit/base	current	history1	history2

Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Certificate 12367

Contact/Location: Service Manager - MENBRE

history2

NONE

NONE

NONE