


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 8391368 (S/N 1374) Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **DIAGNOSIS**

## Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Mar2023	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	hictory?
	MATION		IIIIIIIIIIIIII		•	history2
Sample Number		Client Info		KCPA016058	KCPA001439	
Sample Date	la una	Client Info		08 Apr 2024	30 Mar 2023	
Machine Age	hrs	Client Info		2939 3000	1584	
Oil Age	hrs	Client Info		N/A	N/A	
Oil Changed		Client inio		ABNORMAL	ABNORMAL	
Sample Status				ADNONWAL	ABNORWAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm		>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m		<1	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	19	3	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	<1	
Manganese	ppm	ASTM D5185m		1	<1	
Magnesium	ppm	ASTM D5185m	100	21	40	
Calcium	ppm	ASTM D5185m	0	<1	1	
Phosphorus	ppm	ASTM D5185m	0	2	5	
Zinc	ppm	ASTM D5185m	0	7	0	
Sulfur	ppm	ASTM D5185m	23500	22558	21097	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	4	
Sodium	ppm	ASTM D5185m		10	3	
Potassium	ppm	ASTM D5185m	>20	3	<1	
Water	%	ASTM D6304	>0.05	0.006	<u></u>	
ppm Water	ppm	ASTM D6304	>500	67	<b>▲</b> 1250	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9925		
Particles >6µm		ASTM D7647	>1300	<b>4503</b>		
Particles >14µm		ASTM D7647	>80	<b>172</b>		
Particles >21μm		ASTM D7647	>20	<b>△</b> 32		
Particles >38µm		ASTM D7647	>4	1		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/19/15</b>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.27	0.28	



## **OIL ANALYSIS REPORT**





Laboratory Sample No.

: KCPA016058 Lab Number : 06151170 Unique Number: 10981248

Received : 16 Apr 2024 **Tested** Diagnosed

: 19 Apr 2024 : 19 Apr 2024 - Don Baldridge

101 NORFOLK ST MANSFIELD, MA US 02048 Contact: E TASHO

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

ETASHO@AMERISOURCEBERGEN.COM T:

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: