


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SX 7.5 5252393 (S/N 1022)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ja	.2021	Oct2021 Mar207	4	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016377	KCP39891	KCP27766
Sample Date		Client Info		26 Mar 2024	27 Oct 2021	07 Jan 2021
Machine Age	hrs	Client Info		11441	5407	4896
Oil Age	hrs	Client Info		3608	511	1896
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	<1	3
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	10	0
Barium	ppm	ASTM D5185m	90	0	34	2
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		1	0	<1
Magnesium	ppm	ASTM D5185m	100	29	75	55
Calcium	ppm	ASTM D5185m	0	<1	1	<1
Phosphorus	ppm	ASTM D5185m	0	0	0	7
Zinc	ppm	ASTM D5185m	0	4	6	0
Sulfur	ppm	ASTM D5185m	23500	24714	17189	17784
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	<1
Sodium	ppm	ASTM D5185m		8	16	13
Potassium	ppm	ASTM D5185m	>20	2	2	1
Water	%	ASTM D6304	>0.05	0.006	0.016	0.010
ppm Water	ppm	ASTM D6304	>500	62	165.3	100.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		3410	1568	8444
Particles >6µm		ASTM D7647	>1300	<u> </u>	338	<u>^</u> 2792
Particles >14μm		ASTM D7647	>80	<u>142</u>	19	<u>^</u> 285
Particles >21µm		ASTM D7647	>20	<u>41</u>	5	<u>^</u> 75
Particles >38μm		ASTM D7647	>4	3	0	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/18/14	16/11	△ 19/15
FLUID DEGRADA	TION					

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.346 0.422 Contact/Location: Service Manager - PILBRO



OIL ANALYSIS REPORT







Certificate 12367

Sample No.

Laboratory Lab Number

: 06151183

: KCPA016377 Unique Number: 10981261

Received : 16 Apr 2024 **Tested** Diagnosed

: 19 Apr 2024 : 19 Apr 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

US 80021

12300 PILATUS WAY

Contact: Service Manager

BROOMFIELD, CO