

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id KAESER 5721017

Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013567	KCPA007937	KCP53111
Sample Date		Client Info		10 Apr 2024	04 Oct 2023	01 May 2023
Machine Age	hrs	Client Info		22099	21730	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ATTENTION	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		4	2	3
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	63	73	70
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		1	0	0
Magnesium	ppm	ASTM D5185m	100	60	72	85
Calcium	ppm	ASTM D5185m	0	3	2	4
Phosphorus	ppm	ASTM D5185m	0	0	2	2
Zinc	ppm	ASTM D5185m	0	0	3	4
Sulfur	ppm	ASTM D5185m	23500	25567	20697	21973
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		32	29	32
Potassium	ppm	ASTM D5185m	>20	6	5	6
Water	%	ASTM D6304	>0.05	0.019	0.021	0.026
ppm Water	ppm	ASTM D6304	>500	195	218.1	267.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5837	1598	2213
Particles >6µm		ASTM D7647	>1300	<mark> </mark> 1732	437	724
Particles >14µm		ASTM D7647	>80	<mark> </mark> 139	37	57
Particles >21µm		ASTM D7647	>20	<mark> </mark> 33	9	15
Particles >38µm		ASTM D7647	>4	2	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	e 20/18/14	18/16/12	18/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.35	0.40	0.36


Contact/Location: Service Manager - AMATRA Page 1 of 2





OIL ANALYSIS REPORT












VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	52.4	50.7	51.2
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						

Bottom



: 19 Apr 2024 - Don Baldridge



Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

Report Id: AMATRA [WUSCAR] 06151226 (Generated: 04/19/2024 23:55:36) Rev: 1

Laboratory

Sample No.

Unique Number : 10981304

Contact/Location: Service Manager - AMATRA

US 95377

T:

F:

Contact: Service Manager