


OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
VILTER RESIDUE A
 Component
Compressor
 Fluid
VILTER METHANE PAO 100 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear

An increase in the iron level is noted. The chromium level is abnormal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO60002354	TO60001056	TO60001089
Sample Date	Client Info	03 Apr 2024	02 Oct 2023	07 Sep 2023
Machine Age	hrs	41801	37664	37082
Oil Age	hrs	28578	29160	29912
Oil Changed	Client Info	Oil Added	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	▲ 117	48	55
Chromium	ppm	ASTM D5185m >5	▲ 6	1	2
Nickel	ppm	ASTM D5185m	3	<1	1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >15	<1	0	0
Lead	ppm	ASTM D5185m >65	0	0	0
Copper	ppm	ASTM D5185m >65	2	0	0
Tin	ppm	ASTM D5185m >10	<1	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	2	<1	<1
Magnesium	ppm	ASTM D5185m	<1	0	1
Calcium	ppm	ASTM D5185m	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	<1
Zinc	ppm	ASTM D5185m	0	0	3
Sulfur	ppm	ASTM D5185m	32	20	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >35	<1	0	<1
Sodium	ppm	ASTM D5185m	2	0	0
Potassium	ppm	ASTM D5185m >20	2	0	1
Water	%	ASTM D6304 >0.1	0.006	0.016	0.056
ppm Water	ppm	ASTM D6304 >1000	60	165.7	560






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 300426	▲ 160314	▲ 212558
Particles >6µm	ASTM D7647 >2500	▲ 177869	▲ 39864	▲ 35452
Particles >14µm	ASTM D7647 >320	▲ 587	106	33
Particles >21µm	ASTM D7647 >80	16	21	5
Particles >38µm	ASTM D7647 >20	0	0	0
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 25/25/16	▲ 25/22/14	▲ 25/22/12

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.095	0.037	0.18

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	156	155	155
Visc @ 100°C	cSt	ASTM D445	22.7	22.7	24.49
Viscosity Index (VI)	Scale	ASTM D2270	174	175	191

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO60002354
Lab Number : 06151231
Unique Number : 10981309
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)
Received : 16 Apr 2024
Tested : 19 Apr 2024
Diagnosed : 19 Apr 2024 - Don Baldrige

BLUE RIDGE RENEWABLES
 2200 FM 521
 FRESNO, TX
 US 77545

Contact: Ezequiel Tirado
 ztirado@morrowenergy.com
 T: (214)425-5006
 F: x:
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)