




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

[PMIAS3221625]

Machine Id

GENERAC 5D0200GG178.7 4017299 - HUNTINGTOWN VFDRSC06 (S/N 10027644)

Component

Diesel Engine

Fluid

DIESEL ENGINE OIL SAE 15W40 (7 QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		DC0034965	DC0029903	DC0026727
Sample Date	Client Info		28 Mar 2024	08 Aug 2023	10 May 2023
Machine Age	hrs	Client Info	157	145	341
Oil Age	hrs	Client Info	0	4	0
Oil Changed	Client Info		Not Changed	Not Changd	Changed
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	<1.0
Water	WC Method	>0.2	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	1	2	2
Chromium	ppm	ASTM D5185m >20	<1	<1	0
Nickel	ppm	ASTM D5185m >4	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >20	2	1	<1
Lead	ppm	ASTM D5185m >40	<1	<1	<1
Copper	ppm	ASTM D5185m >330	8	4	1
Tin	ppm	ASTM D5185m >15	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 250	6	5	5
Barium	ppm	ASTM D5185m 10	0	0	2
Molybdenum	ppm	ASTM D5185m 100	4	6	8
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m 450	54	67	96
Calcium	ppm	ASTM D5185m 3000	2338	2066	2118
Phosphorus	ppm	ASTM D5185m 1150	975	825	853
Zinc	ppm	ASTM D5185m 1350	1070	971	1008
Sulfur	ppm	ASTM D5185m 4250	3992	3832	3854

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	3	4	3
Sodium	ppm	ASTM D5185m >158	1	<1	0
Potassium	ppm	ASTM D5185m >20	2	2	1

INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	0	0	0
Nitration	Abs/cm	*ASTM D7624 >20	4.9	4.7	4.9
Sulfation	Abs/.1mm	*ASTM D7415 >30	15.2	14.8	15.8

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	9.3	9.1	9.4
Base Number (BN)	mg KOH/g	ASTM D2896 8.5	7.4	7.3	7.9











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	13.8	13.4

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0034965 **Received** : 17 Apr 2024
Lab Number : 06151830 **Tested** : 18 Apr 2024
Unique Number : 10981908 **Diagnosed** : 18 Apr 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: TBN)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)