


OIL ANALYSIS REPORT

Sample Rating Trend







No. 3 Paper Machine 3 PM FAN PUMP (S/N 10378-P) Pump

ROYAL PURPLE SYNFILM 100 (25 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		112020 00020	20 May2021 002021	THE COLD CONTROL TO SEC.	002020	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0039763	RP06120861	RP0038219
Sample Date		Client Info		16 Apr 2024	17 Mar 2024	15 Feb 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	<1	0	0
Chromium	ppm	ASTM D5185m	>5	0	<1	0
Nickel	ppm	ASTM D5185m	>5	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	0	<1	<1
Lead	ppm	ASTM D5185m	>12	0	0	<1
Copper	ppm	ASTM D5185m	>30	<1	<1	<1
Tin	ppm	ASTM D5185m	>9	0	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	73	90	86
Calcium	ppm	ASTM D5185m		3	<1	41
Phosphorus	ppm	ASTM D5185m		3	2	2
Zinc	ppm	ASTM D5185m		<1	0	4
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	0	<1	<1
Sodium	ppm	ASTM D5185m		11	9	8
Potassium	ppm	ASTM D5185m	>20	7	0	2
Water	%	ASTM D6304	>.1	0.017	0.009	0.013
ppm Water	ppm	ASTM D6304	>1000	176	100	137
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	246	211	297
Particles >6µm		ASTM D7647	>1300	75	39	69
Particles >14μm		ASTM D7647	>160	10	5	5
Particles >21µm		ASTM D7647	>40	4	2	2
Particles >38μm		ASTM D7647	>10	1	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	15/13/10	15/12/10	15/13/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.25	0.37	0.39	0.36



OIL ANALYSIS REPORT







Certificate 12367

Sample No. Lab Number

Laboratory

Unique Number : 10982052

: RP0039763 : 06151974

Received **Tested** Diagnosed

: 17 Apr 2024

: 18 Apr 2024

: 19 Apr 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: DAVID COTHREN - INTTEX

9978 FM 3129

US 75572

QUEEN CITY, TX

T: (903)796-1690

F: (903)796-1969

Contact: DAVID COTHREN

david.cothren@graphicpkg.com