


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 6512034

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

A Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


KC105621 21 Feb 2023 35048 6000 Changed ATTENTION 6 10 3 3 3 4 1 3 3 4 3 3 4 3 3 3 5 4 3 3 3 5 4 3 3 3 3	KC103525 25 May 2022 28578 6000 Changed ABNORMAL history2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
35048 6000 Changed ATTENTION <100 <100 <100 <1000 1000 1000 000 000	28578 6000 Changed ABNORMAL 0 0 0 0 0 0 0 0 0 0 0 14 0 0 0 0 14 0 0 0 0 14 2 0 0 0 14 2 0 0
6000 Changed ATTENTION 	6000 Changed ABNORMAL 0 0 0 0 0 0 0 0 0 0 14 0 0 0 0 14 0 0 0 0 14 2 0 0
Changed ATTENTION history1 <1 0 <1 0 <1 0 <1 0 0 10 0 0 0 0 history1 0 2	Changed ABNORMAL 0 0 0 0 0 0 0 0 0 0 14 0 0 0 0 0 14 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
ATTENTION history1 <1 0 <1 0 <1 <1 0 10 0 10 0 0 0 0 0 0	ABNORMAL history2 0 0 0 0 0 0 0 14 0 0 0 0 0 0 0 14 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
<1	history2 0 0 0 0 0 0 14 <1
<1 0 <1 0 <1 <1 0 10 0 10 0 0 0 0 history1 0 2	0 0 0 0 0 1 1 4 <1 0 1 4 <1 0 0 0 0 history2 2 0
0 <1 0 <1 0 10 0 0 0 0 history1 0 2	0 0 0 0 1 1 4 <1 0 0 0 0 history2 2 0
<1 0 <1 <1 0 10 0 0 0 0 history1 0 2	0 0 () () () () () () () () () () () () ()
0 <1 <1 0 10 0 0 0 0 0 0 0 2	0 0 <1 0 14 <1 0 0 0 history2 2 0
<1 <1 0 10 0 0 0 0 history1 0 2	0 <1 0 14 <1 0 0 0 history2 2 0
<1 0 10 0 0 0 0 history1 0 2	<1 0 14 <1 0 0 0 history2 2 0
0 10 0 0 0 0 <u>history1</u> 0 2	0 14 <1 0 0 0 history2 2 0
0 10 0 0 0 0 <u>history1</u> 0 2	14 <1 0 0 0 history2 2 0
10 0 0 0 0 <u>history1</u> 0 2	14 <1 0 0 0 history2 2 0
0 0 0 0 history1 0 2	<1 0 0 history2 2 0
 0 0 <u>history1</u> 0 2	0 0 history2 2 0
0 history1 0 2	0 history2 2 0
0 history1 0 2	0 history2 2 0
history1 0 2	history2 2 0
0	2
2	0
0	0
0	0
0	0
1	0
÷	0
<1	2
44	9
history1	history2
0	0
	0
2	0
0.009	0.011
96.8	118.1
history1	history2
3391	6692
1390	▲ 3099
51	97
11	12
0	1
0	0
9/18/13	▲ 20/19/14
	history2
history1	matoryz
	3 2 0.009 96.8 history1 3391 1390 51 11 0 0 0 19/18/13

Contact/Location: Service Manager - SENEVA Page 1 of 2



OIL ANALYSIS REPORT






	10000-	0					****	
(mdd)	8000-							
ater (pp	6000							
8	4000							
	2000	Abnormal						
	01				-	2.		-
		Nov21/1	Mar20/2	Dec2/2	Sep 2/2	May25/2	Feb 21/2	AE.19.

Certificate 12367




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.4	45.2	44.6
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color



Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact/Location: Service Manager - SENEVA