

OIL ANALYSIS REPORT

KAESER 01115987 - PENSKE FRANKLIN PARK

Component Compressor

Area

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






SAMPLE INFORM	ΛΑΤΙΟΝ	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000189	UCH05995704	
Sample Date		Client Info		11 Apr 2024	31 Oct 2023	
Machine Age	hrs	Client Info		86903	84133	
Oil Age	hrs	Client Info		2000	4000	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	0	3	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.1	0	0	
Barium	ppm	ASTM D5185m	0.8	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	0.9	0	0	
Magnesium	ppm	ASTM D5185m	0	2	0	
Calcium	ppm	ASTM D5185m	0	2	0	
Phosphorus	ppm	ASTM D5185m	409	262	211	
Zinc	ppm	ASTM D5185m	0	23	0	
Sulfur	ppm	ASTM D5185m	1290	548	944	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		0	<1	
Potassium	ppm	ASTM D5185m	>20	0	1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.537	0.31	0.21	



38 0ct31/23

OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	LIGHT	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Apr11/24	Appearance	scalar	*Visual	NORML	NORML	NORML	
Apr	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
	Free Water	scalar	*Visual		NEG	NEG	
	FLUID PROPER	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	44.56	44.4	43.7	
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Apri 1/24	Color						no image
	Bottom						no image
	2						
	Non-ferrous Meta	ls		Apri 1/24			
	Non-ferrous Meta			Apri1/24			
	Viscosity @ 40°C			Apri1/24	Acid Number		
	Non-ferrous Meta			Apri1/24	Acid Number		
	Non-ferrous Meta			Apri1/24	Acid Number		
	Non-ferrous Meta			Apri1/24	Acid Number		
	Non-ferrous Meta			Apri1/24	Acid Number		
	Non-ferrous Meta			4011/24 4011/24 0.0 0.0 0.0 0.0	Acid Number		
	Non-ferrous Meta			4011/24 4011/24 0.0 0.0 0.0 0.0	0 Base		
	Non-ferrous Meta Copper lead tin lead Viscosity @ 40°C Solution Abnomal Abnomal			40011/24 40011/24 0.0 0.0 0.0 0.0	Acid Number		
Laboratory Sample No.	Non-ferrous Meta Copper Viscosity @ 40°C Copy 45 Abnomal Base Element Base Element Base Element Base Element	01 Madisc Recei	ived : 17	⁶⁰ HOX bul Jone ⁶⁰ HOX bul	8 6 4 2 2 0 5 7 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		WNERS GROV TISS STREE
	Non-ferrous Meta Copper Viscosity @ 40°C Viscosity @ 40°C Copper Viscosity @ 40°C Copper Co	01 Madisc Rece Teste Diagr	ived : 17 ed : 18 nosed : 19 800-237-1368	P211100 P21100 P21100 P2110	DELTA	2201 CUR	TISS STREE RS GROVE, I US 6051

Report Id: UCDELDOW [WUSCAR] 06152064 (Generated: 04/20/2024 09:49:13) Rev: 1

Contact/Location: MICHAEL FERRIS - UCDELDOW