


OIL ANALYSIS REPORT

Sample Rating Trend





KAESER S-460 **KAESER 1053 - PANDUIT**

Component Compressor

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000123	UCH05982469	UCH05902392
Sample Date		Client Info		08 Apr 2024	06 Oct 2023	10 Jul 2023
Machine Age	hrs	Client Info		21863	21055	19284
Oil Age	hrs	Client Info		4014	3206	2000
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				ATTENTION	ATTENTION	NORMAL
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	8	5
Tin	ppm	ASTM D5185m	>10	5	4	3
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	23	18	29
Calcium	ppm	ASTM D5185m	2	3	0	0
Phosphorus	ppm	ASTM D5185m		<1	16	5
Zinc	ppm	ASTM D5185m		0	1	7
Sulfur	ppm	ASTM D5185m		19180	16987	19783
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	57	5 6	24
Sodium	ppm	ASTM D5185m		24	17	20
Potassium	ppm	ASTM D5185m	>20	3	2	0
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.27	0.33



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

1 LOID I HOI LITT						
Visc @ 40°C	cSt	ASTM D445	46	45.2	44.9	44.8


SAMPLE IMAGES				
---------------	--	--	--	--


Color







GRAPHS













Certificate 12367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. Lab Number : 06152069

: UDI0000123 Unique Number : 10982147

Received : 17 Apr 2024 **Tested** : 18 Apr 2024 Diagnosed

: 19 Apr 2024 - Sean Felton

2201 CURTISS STREET DOWNERS GROVE, IL US 60515 Contact: MICHAEL FERRIS

DELTA INDUSTRIES - DOWNERS GROVE

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (630)960-3931 Contact/Location: MICHAEL FERRIS - UCDELDOW

Report Id: UCDELDOW [WUSCAR] 06152069 (Generated: 04/20/2024 09:49:47) Rev: 1