


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

GARDNER DENVER 1300 CPR 003

Component Compressor

GARDNER DENVER AEON 9000 SP (30 GA

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


L)		Jun2023	Jul2023 Sep2023	Oct2023 Dec2023	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number	VII) (11101 V	Client Info	mmrsacc	PH0002822	PH0001954	PH0001953
Sample Date		Client Info		04 Apr 2024	07 Dec 2023	29 Oct 2023
Machine Age	hrs	Client Info		54465	07 Dec 2023	51291
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1115	Client Info		N/A	N/A	Changed
Sample Status		Ciletit IIIIO		NORMAL	NORMAL	ABNORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water	IN	WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	0
Lead	ppm	ASTM D5185m	>25	0	0	<1
Copper	ppm	ASTM D5185m	>50	<1	<1	0
Soppei Tin		ASTM D5185m	>15	<1	0	0
vanadium	ppm	ASTM D5185m	>10	0	0	0
Variadium Cadmium	ppm	ASTM D5185m		0	0	0
	ppm		11 11 11			
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1 1
Barium	ppm	ASTM D5185m	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	0	0	0	<1
Calcium	ppm	ASTM D5185m	0	3	1	<1
Phosphorus 	ppm	ASTM D5185m	800	872	802	799
Zinc	ppm	ASTM D5185m	0	0	0	1
Sulfur	ppm	ASTM D5185m	0	23	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		1	2	<1
Potassium	ppm	ASTM D5185m	>20	2	0	0
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	1547	2423	<u>▲</u> 51786
Particles >6µm		ASTM D7647	>2500	575	607	<u> </u>
Particles >14μm		ASTM D7647	>320	87	59	△ 1038
Particles >21µm		ASTM D7647	>80	33	19	<u>^</u> 268
Particles >38µm		ASTM D7647	>20	1	1	13
Particles >71μm		ASTM D7647	>4	0	0	1
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/14	18/16/13	2 3/21/17
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	ma K∩U/a	ACTM DOME	170	0.35	0.40	0.46




OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method				history2
Visc @ 40°C	cSt	ASTM D445	49.01	48.3	49.7	48.9

	1AGES

Color

Bottom

PrtFilter



GRA	PHS										
Ferro	us Alloys						cle Cou	nt			20
E. 5.	iron chromium nickel					122,880 Severe					T26
Jun3/23	Jul22/23	Sep24/23	0ct29/23	Dec7/23	Apr4/24	30.720 Abnorma 7,680 1 1,920 480		٠.,			-22 ISO 4406:1
	errous M						1				18 1999 Cleanliness Code
Ed 5-	···· tin					120 - 30 - 8 -			1		12 Code
Jun3/23	Jul22/23	Sep24/23.	Oct29/23 •	Dec7/23	Apr4/24	2	6				-8
	Viscosity @ 40°C								30μ	Πμ	
Severe Street	ai		****			3.00 Severe					
Severe	al					Abnom	nal				
30 + SZ/Sun3/Z3	Jui22/23	Sep24/23	0ct29/23	Dec7/23 + -	Apr4/24	Acid Number mg KOH/g)	Jui22/23	Sep24/23	0ct29/23	Dec7/23	Apr4/24





Certificate 12367

Laboratory Sample No. Lab Number : 06152584

Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PH0002822 $\textbf{Unique Number} \quad : 10982662$

Received **Tested** Diagnosed

: 17 Apr 2024 : 22 Apr 2024

: 22 Apr 2024 - Doug Bogart

APCOM 127 SOUTHEAST PARKWAY

FRANKLIN, TN US 37064

Contact: R Filipovic rfilipovic@apcom.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: