




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER ASD 40ST 6188580 (S/N 4463)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

The oil change at the time of sampling has been noted. We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

Appearance is hazy. There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCPA014883</b>	KCP52477	KCP32358
Sample Date	Client Info			<b>13 Mar 2024</b>	09 Feb 2023	28 Jun 2021
Machine Age	hrs	Client Info		<b>42549</b>	0	22952
Oil Age	hrs	Client Info		<b>0</b>	0	5224
Oil Changed	Client Info			<b>Changed</b>	N/A	Changed
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>3</b>	<1	<1
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m	>10	<b>2</b>	0	0
Lead	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m	>50	<b>11</b>	5	8
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	0
Antimony	ppm	ASTM D5185m		<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	90	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	90	<b>5</b>	0	<1
Calcium	ppm	ASTM D5185m	2	<b>4</b>	0	0
Phosphorus	ppm	ASTM D5185m		<b>17</b>	2	3
Zinc	ppm	ASTM D5185m		<b>16</b>	0	0
Sulfur	ppm	ASTM D5185m		<b>20081</b>	14828	11970

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	0
Sodium	ppm	ASTM D5185m		<b>10</b>	<1	0
Potassium	ppm	ASTM D5185m	>20	<b>3</b>	0	<1
Water	%	ASTM D6304	>0.05	<b>▲ 0.237</b>	0.014	▲ 0.319
ppm Water	ppm	ASTM D6304	>500	<b>▲ 2370</b>	146.4	▲ 3190

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>1644</b>	41729	---
Particles >6µm		ASTM D7647	>1300	<b>896</b>	▲ 8230	---
Particles >14µm		ASTM D7647	>80	<b>● 152</b>	▲ 139	---
Particles >21µm		ASTM D7647	>20	<b>● 51</b>	14	---
Particles >38µm		ASTM D7647	>4	<b>● 8</b>	0	---
Particles >71µm		ASTM D7647	>3	<b>1</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	<b>● 18/17/14</b>	▲ 23/20/14	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	<b>0.51</b>	0.37	0.370


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	47.86	44.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA014883  
**Lab Number** : 06152589  
**Unique Number** : 10982667  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )  
**Received** : 17 Apr 2024  
**Tested** : 23 Apr 2024  
**Diagnosed** : 23 Apr 2024 - Jonathan Hester

**STAR PRECISION**  
 5410 BRYSTONE ST  
 HOUSTON, TX  
 US 77041  
 Contact: SERVICE MANAGER



Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)