


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SM 10 7836066 (S/N 1669)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. Excessive free water present.


Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
		Client Info	minu bacc	KCPA012543	KCP49179	
Sample Number		Client Info				
Sample Date	hvo	Client Info		12 Apr 2024 3223	07 Feb 2023 2238	
Machine Age	hrs	Client Info		0	2238	
Oil Age Oil Changed	1115	Client Info		Not Changd	Changed	
Sample Status		Ciletit IIIIO		ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m		0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	0	
Lead	ppm	ASTM D5185m	>10	<1	<1	
Copper	ppm	ASTM D5185m	>50	1	2	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	8	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	47	38	
Calcium	ppm	ASTM D5185m	0	4	<1	
Phosphorus	ppm	ASTM D5185m	0	3	5	
Zinc	ppm	ASTM D5185m	0	0	7	
Sulfur	ppm	ASTM D5185m	23500	22272	19615	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		4	10	
Potassium	ppm	ASTM D5185m	>20	3	2	
Water	%	ASTM D6304	>0.05	△ 0.218	0.037	
ppm Water	ppm	ASTM D6304	>500	2180	377.3	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			1439	
Particles >6µm		ASTM D7647	>1300		476	
Particles >14µm		ASTM D7647	>80		19	
Particles >21µm		ASTM D7647	>20		4	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		18/16/11	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.38	0.33	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06152595 Unique Number : 10982673

: KCPA012543

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received **Tested** Diagnosed

: 17 Apr 2024 : 22 Apr 2024

: 22 Apr 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

SALINAS, CA US 93901 Contact: Service Manager vendor@sierranaturalscience.com

1031 INDUSTRIAL ST, UNIT C

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: