

OIL ANALYSIS REPORT

Sample Rating Trend SEDIMENT

Machine Id KAESER SK 19 1420229 (S/N 01810118)

Component Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017159	KCP55607	KCP45313
Sample Date		Client Info		02 Apr 2024	20 Jan 2023	04 Apr 2022
Machine Age	hrs	Client Info		88092	83017	78753
Oil Age	hrs	Client Info		4000	4264	0
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		2	3	2
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ppm		11			
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	4	4	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	4.0.0	<1	0	0
Magnesium	ppm	ASTM D5185m	100	62	78	83
Calcium	ppm	ASTM D5185m	0	6	5	4
Phosphorus	ppm	ASTM D5185m	0	<1	5	3
Zinc	ppm	ASTM D5185m	0	0	9	0
Sulfur	ppm	ASTM D5185m	23500	23146	18457	17468
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	<1
Sodium	ppm	ASTM D5185m		25	32	28
Potassium	ppm	ASTM D5185m	>20	8	6	5
Water	%	ASTM D6304	>0.05	0.020	0.018	0.031
ppm Water	ppm	ASTM D6304	>500	207	189.3	316.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			10510	99876
Particles >6µm		ASTM D7647	>1300		A 3562	🔺 28916
Particles >14µm		ASTM D7647	>80		A 271	1326
Particles >21µm		ASTM D7647	>20		4 9	A 231
Particles >38µm		ASTM D7647	>4		3	3
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		1 /19/15	▲ 22/18
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN) :12:55) Rev: 1	mg KOH/g	ASTM D8045		0.36	0.39 ion: TROY HOL	0.35


Report Id: VWRSUW [WUSCAR] 06152615 (Generated: 04/23/2024 14:12:55) Rev: 1


Contact/Location: TROY HOUSE - VWRSUW



OIL ANALYSIS REPORT









VISUAL method limit/base history1 history2 current NONE NONE White Metal *Visual NONE NONE scalar Yellow Metal *Visual NONE NONE NONE NONE scalar NONE Precipitate scalar *Visua NONE NONE NONE Silt scalar *Visual NONE MODER NONE NONE *Visual MODER Debris NONE NONE LIGHT scalar Sand/Dirt NONE NONE scalar *Visual NONE NONE NORML NORML Appearance scalar *Visual NORML NORML Odor *Visual NORML NORML NORML NORML scalar **Emulsified Water** scalar *Visual >0.05 NEG NEG NEG Free Water scalar *Visual NEG NEG NEG FLUID PROPERTIES method limit/base curren history history2 50.1 Visc @ 40°C cSt ASTM D445 45 48.6 47.1 SAMPLE IMAGES limit/base history2 method current history1

Color



Bottom





Unique Number : 10982693 Diagnosed : 22 Apr 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 TROY.HOUSE@AVANTORSCIENCES.COM To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: VWRSUW [WUSCAR] 06152615 (Generated: 04/23/2024 14:12:55) Rev: 1

Laboratory

Contact/Location: TROY HOUSE - VWRSUW

T:

F:

Contact: TROY HOUSE