


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id

KAESER DSD-250 3855611 (S/N 1029)

Component Compressor

CAS-2015-46 (--- GAL)



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC122650	KC101062	KC95658
Sample Date		Client Info		29 Jan 2024	16 May 2023	12 Jan 2023
Machine Age	hrs	Client Info		39588	33438	30469
Oil Age	hrs	Client Info		0	1268	2472
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	2	<1
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	1	<1
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		<1	0	0
Phosphorus	ppm	ASTM D5185m		362	299	153
Zinc	ppm	ASTM D5185m		0	68	7
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		2	0	1
Potassium	ppm	ASTM D5185m	>20	2	1	0
Water	%	ASTM D6304	>0.1	0.006	0.012	0.010
ppm Water	ppm	ASTM D6304	>1000	65	122.5	103.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		892	1885	3410
Particles >6μm		ASTM D7647	>1300	309	448	1070
Particles >14μm		ASTM D7647	>80	40	36	59
Particles >21µm		ASTM D7647	>20	15	8	12
Particles >38μm		ASTM D7647	>4	1	2	2
Particles >71μm		ASTM D7647	>3	0	1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	18/16/12	19/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42	1.18	0.71



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: KC122650 : 06152618 Unique Number : 10982696 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received : 17 Apr 2024 **Tested** : 22 Apr 2024 Diagnosed : 22 Apr 2024 - Don Baldridge

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER - CUTLAK

CUTRALE CITRUS JUICES

Contact: SERVICE MANAGER

602 MCKEAN ST

LAKELAND, FL

US 33823

T:

F: