

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER AIRCENTER SM 10 4691709 (S/N 2656)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan 201	7 Apr2018	Sep2019 Ma	2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016853	KCP18534	KCP08100
Sample Date		Client Info		25 Mar 2024	05 Sep 2019	01 Apr 2018
Machine Age	hrs	Client Info		38257	22151	20036
Oil Age	hrs	Client Info		2667	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	3	8	19
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m			0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	0
Barium	ppm	ASTM D5185m	90	54	20	18
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	56	46	37
Calcium	ppm	ASTM D5185m	0	4	1	1
Phosphorus	ppm	ASTM D5185m	0	16	2	4
Zinc	ppm	ASTM D5185m	0	0	12	19
Sulfur	ppm	ASTM D5185m	23500	21038	18173	17453
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		24	16	15
Potassium	ppm	ASTM D5185m	>20	4	1	0
Water	%	ASTM D6304	>0.05	0.020	0.023	0.011
ppm Water	ppm	ASTM D6304	>500	208	235.6	110
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2273	7384	6539
Particles >6µm		ASTM D7647	>1300	551	2443	2164
Particles >14μm		ASTM D7647	>80	28	124	△ 283
Particles >21µm		ASTM D7647	>20	9	28	<u>▲</u> 81
Particles >38μm		ASTM D7647	>4	1	1	5
Particles >71μm		ASTM D7647	>3	0	0	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	18/14	<u>▲</u> 18/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number

: 06153150 Unique Number : 10983228

: KCPA016853

Received **Tested** Diagnosed

: 19 Apr 2024

: 18 Apr 2024

: 22 Apr 2024 - Don Baldridge

200 N MAIN ST MEMPHIS, TN US 38103

Contact: SERVICE MANAGER

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER ? - FEDMEMTN

T:

F: