




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**KAESER 7997306**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KC06153797</b>	KC106455	KC106447
Sample Date	Client Info			<b>26 Mar 2024</b>	30 Nov 2022	17 Nov 2022
Machine Age	hrs	Client Info		<b>4044</b>	1911	1911
Oil Age	hrs	Client Info		<b>0</b>	1911	1911
Oil Changed	Client Info			<b>N/A</b>	Changed	Not Changed
Sample Status				<b>ABNORMAL</b>	NORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>2</b>	0	<1
Chromium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>2</b>	0	1
Lead	ppm	ASTM D5185m	>10	<b>1</b>	0	<1
Copper	ppm	ASTM D5185m	>50	<b>11</b>	7	7
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	<1
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	90	<b>2</b>	0	0
Molybdenum	ppm	ASTM D5185m	0	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	100	<b>15</b>	4	6
Calcium	ppm	ASTM D5185m	0	<b>4</b>	0	1
Phosphorus	ppm	ASTM D5185m	0	<b>7</b>	10	8
Zinc	ppm	ASTM D5185m	0	<b>74</b>	15	17

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>1</b>	0	<1
Sodium	ppm	ASTM D5185m		<b>7</b>	1	4
Potassium	ppm	ASTM D5185m	>20	<b>5</b>	3	5
Water	%	ASTM D6304	>0.05	<b>0.011</b>	0.011	▲ 0.091
ppm Water	ppm	ASTM D6304	>500	<b>116</b>	115.6	▲ 913.2

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>17682</b>	1538	10120
Particles >6µm		ASTM D7647	>1300	▲ <b>3441</b>	457	▲ 2964
Particles >14µm		ASTM D7647	>80	▲ <b>287</b>	22	▲ 292
Particles >21µm		ASTM D7647	>20	▲ <b>100</b>	7	▲ 107
Particles >38µm		ASTM D7647	>4	▲ <b>9</b>	1	▲ 7
Particles >71µm		ASTM D7647	>3	▲ <b>1</b>	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ <b>21/19/15</b>	18/16/12	▲ 21/19/15

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.37</b>	0.33	0.32


# OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	44.5	44.0	43.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC06153797  
**Lab Number** : 06153797  
**Unique Number** : 10989220  
**Test Package** : IND 2  
**Received** : 18 Apr 2024  
**Tested** : 23 Apr 2024  
**Diagnosed** : 23 Apr 2024 - Don Baldrige

**CHARIOT EAGLE LLC**  
 931 NW 37TH AVE  
 OCALA, FL  
 US 34475  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)