


# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**BT-FOR-A7 (S/N TANK FT7 AGITATOR)**  
Component  
**Gearbox**  
Fluid  
**SHELL OMALA S2 GX 220 (--- GAL)**

## DIAGNOSIS

### Recommendation

Ferrous wear rate has returned to the typical trend. The is sufficient visual evidence (above 40 micron particles) that a particle count could not be performed. If this unit is being sampled from a drain line RESAMPLE and be sure to flush the drain line before collecting the sample. The unit should be filtered using B6=75 quality filter media to remove particulate and wear debris.

### Wear

Fe wear rate is within the typical historical range for this drive. Fe wear rates are always higer with drives given their operating contact modes, but filtration helps to control the wear rate.

### Contamination

Particle count could not be provided due to the debris in the oil. Filtration is strongly recommended.

### Fluid Condition

Fluid health properties suggest oil is acceptable for continued use.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PLS0000298</b>	PLS0000718	PLS0000784
Sample Date	Client Info		<b>17 Apr 2024</b>	31 Jan 2024	25 Oct 2023
Machine Age	mths	Client Info	<b>3</b>	3	0
Oil Age	mths	Client Info	<b>0</b>	0	1
Oil Changed	Client Info		<b>N/A</b>	N/A	Changed
Sample Status			<b>ABNORMAL</b>	SEVERE	SEVERE

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>▲ 117</b>	▲ 207	48
Iron	ppm	ASTM D5185m >200	<b>▲ 89</b>	▲ 84	56
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 6.2	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 0.0	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>1</b>	<1	<1
Magnesium	ppm	ASTM D5185m 0	<b>4</b>	1	0
Calcium	ppm	ASTM D5185m 0.0	<b>6</b>	5	0
Phosphorus	ppm	ASTM D5185m 290	<b>317</b>	303	218
Zinc	ppm	ASTM D5185m 3.8	<b>2</b>	15	0
Sulfur	ppm	ASTM D5185m 8167	<b>12141</b>	9749	8641

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	3	1
Sodium	ppm	ASTM D5185m	<b>2</b>	0	1
Potassium	ppm	ASTM D5185m >20	<b>2</b>	0	0






## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0	0
Nitration	Abs/cm	*ASTM D7624	<b>3.1</b>	3.0	3.0
Sulfation	Abs/.1mm	*ASTM D7415	<b>12.3</b>	12.1	12.1

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	<b>3.1</b>	2.9	3.0
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.49</b>	0.48	0.44


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	215	210

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000298 **Received** : 19 Apr 2024  
**Lab Number** : 06154200 **Tested** : 06 May 2024  
**Unique Number** : 10989623 **Diagnosed** : 07 May 2024 - Mike Johnson  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ )

**HEXION - BAYTOWN PLANT**  
 8450 WEST BAY RD  
 BAYTOWN, TX  
 US 77520  
 Contact: BILL MINER  
 bill.miner@momentive.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)