


# PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id  
**BT-FOR-A3 (S/N TANK FT3 AGITATOR)**  
Component  
**Gearbox**  
Fluid  
**SHELL OMALA S2 GX 220 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 162090	▲ 184263	▲ 164595
Particles >6µm	ASTM D7647	>5000	▲ 117851	▲ 136492	▲ 72877
Particles >14µm	ASTM D7647	>640	▲ 7921	▲ 10385	● 1139
Particles >21µm	ASTM D7647	>160	▲ 287	▲ 381	60
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 25/24/20	▲ 25/24/21	▲ 25/23/17

Customer Id: MOMBAY  
Sample No.: PLS0000870  
Lab Number: 06154202  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Mike Johnson +1 (615)771-6030  
[mike.johnson@amrri.com](mailto:mike.johnson@amrri.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### WEAR



#### 31 Jan 2024 Diag: Mike Johnson

Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval. Iron wear particles are elevated from previous samples. This could indicate accelerated wear. Particle contamination is elevated. Filtration can help extend machine life. Fluid health is acceptable for continued use provided that contamination is brought under control.

view report



### ISO



#### 25 Oct 2023 Diag: Mike Johnson

Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval. Wear particles are low and acceptable. Particle contamination is elevated. Filtration can help extend machine life. Fluid health is acceptable for continued use provided that contamination is brought under control.

view report



### NORMAL



#### 09 Aug 2023 Diag: Mike Johnson


No action required at this time. Resample at next normal interval. Wear particles are low and acceptable. Contamination is on par with new unfiltered oil. Filtration can help to extend machine life. Fluid health indicators are acceptable for continued use.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**BT-FOR-A3 (S/N TANK FT3 AGITATOR)**  
Component  
**Gearbox**  
Fluid  
**SHELL OMALA S2 GX 220 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval.

### Wear

Iron wear particles are elevated from previous samples. This could indicate accelerated wear

### ▲ Contamination

Particle contamination is elevated. Filtration can help extend machine life.

### Fluid Condition

Fluid health is acceptable for continued use provided that contamination is brought under control.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PLS0000870</b>	PLS0000809	PLS0000780
Sample Date	Client Info			<b>17 Apr 2024</b>	31 Jan 2024	25 Oct 2023
Machine Age	mths	Client Info		<b>3</b>	3	0
Oil Age	mths	Client Info		<b>0</b>	0	1
Oil Changed	Client Info			<b>N/A</b>	N/A	Changed
Sample Status				<b>SEVERE</b>	SEVERE	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.2	<b>NEG</b>	NEG	NEG






WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		<b>73</b>	▲ 153	36
Iron	ppm	ASTM D5185m	>200	<b>101</b>	▲ 114	59
Chromium	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	<1
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Lead	ppm	ASTM D5185m	>100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>200	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	6.2	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	0.0	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>1</b>	1	<1
Magnesium	ppm	ASTM D5185m	0	<b>4</b>	2	0
Calcium	ppm	ASTM D5185m	0.0	<b>4</b>	5	0
Phosphorus	ppm	ASTM D5185m	290	<b>306</b>	302	193
Zinc	ppm	ASTM D5185m	3.8	<b>2</b>	15	0
Sulfur	ppm	ASTM D5185m	8167	<b>12562</b>	9699	8473

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<b>1</b>	2	<1
Sodium	ppm	ASTM D5185m		<b>2</b>	0	2
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	0	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0
Nitration	Abs/cm	*ASTM D7624		<b>3.1</b>	3.0	3.0
Sulfation	Abs.1mm	*ASTM D7415		<b>12.4</b>	12.2	12.4

# OIL ANALYSIS REPORT



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000870 **Received** : 19 Apr 2024  
**Lab Number** : **06154202** **Tested** : 06 May 2024  
**Unique Number** : 10989625 **Diagnosed** : 07 May 2024 - Mike Johnson  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ, PrtCount )

**HEXION - BAYTOWN PLANT**  
 8450 WEST BAY RD  
 BAYTOWN, TX  
 US 77520  
 Contact: BILL MINER  
 bill.miner@momentive.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F:

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ <b>162090</b>	▲ 184263	▲ 164595
Particles >6µm	ASTM D7647	>5000	▲ <b>117851</b>	▲ 136492	▲ 72877
Particles >14µm	ASTM D7647	>640	▲ <b>7921</b>	▲ 10385	● 1139
Particles >21µm	ASTM D7647	>160	▲ <b>287</b>	▲ 381	60
Particles >38µm	ASTM D7647	>40	<b>4</b>	2	0
Particles >71µm	ASTM D7647	>10	<b>0</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>25/24/20</b>	▲ 25/24/21	▲ 25/23/17

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414		<b>2.9</b>	2.9	3.3
Acid Number (AN)	mg KOH/g ASTM D8045		<b>0.57</b>	0.60	0.58

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar *Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar *Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar *Visual	>0.2	<b>NEG</b>	NEG	NEG
Free Water	scalar *Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	220	<b>214</b>	213	211

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color



Bottom

