


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# Machine Id VAC A (S/N 5610X82)

Component Compressor

CPI ENG. 6005-32 (--- GAL)

DI			

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Nov2023	Dec2023 Jan2024	Feb2024 Mar2024	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0865071	WC0865041	WC0865088
Sample Date		Client Info		09 Apr 2024	08 Mar 2024	14 Feb 2024
Machine Age	hrs	Client Info		32662	31980	31347
Oil Age	hrs	Client Info		3819	3137	2504
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	4	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>25	0	0	<1
Copper	ppm	ASTM D5185m	>50	0	0	<1
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	1
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1795	1640	1666
Sodium	ppm	ASTM D5185m		0	<1	1
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.1	0.002	0.002	0.001
ppm Water	ppm	ASTM D6304	>1000	22	24	5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	715	3229	1098
Particles >6μm		ASTM D7647	>2500	145	487	224
Particles >14μm		ASTM D7647	>320	5	11	11
Particles >21µm		ASTM D7647	>80	1	3	2
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/14/10	19/16/11	17/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.014	0.014	0.014



## **OIL ANALYSIS REPORT**







Certificate 12367

Sample No. Lab Number

Laboratory

: WC0865071 : 06154481 Unique Number : 10989904

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received : 19 Apr 2024 **Tested** 

: 25 Apr 2024 Diagnosed Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 25 Apr 2024 - Jonathan Hester

US 46221 Contact: William Prestin william.prestin@edlenergy.com T:

2319 KENTUCKY AVE

INDIANAPOLIS, IN

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: KININDIN [WUSCAR] 06154481 (Generated: 04/25/2024 19:17:51) Rev: 1

Contact/Location: William Prestin - KININDIN

F: