


OIL ANALYSIS REPORT

Area

CHEMLUBE PLUS 10 SULLAIR 200611140099 - MICHAELS FINER MEATS

Component Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|------------------|----------|-------------|------------|-------------|-------------|-------------|
| Sample Number | | Client Info | | UCH06154505 | UCH06068609 | UCH05995813 |
| Sample Date | | Client Info | | 16 Apr 2024 | 10 Jan 2024 | 30 Oct 2023 |
| Machine Age | hrs | Client Info | | 125638 | 123307 | 121580 |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | NORMAL | NORMAL | ATTENTION |
| CONTAMINATION | | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | NEG | NEG |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | <1 | 2 | 27 |
| Chromium | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >25 | 1 | <1 | 2 |
| Lead | ppm | ASTM D5185m | >25 | <1 | <1 | 3 |
| Copper | ppm | ASTM D5185m | >50 | 4 | 4 | 58 |
| Tin | ppm | ASTM D5185m | >15 | <1 | <1 | <1 |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 0.1 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 0.8 | 2 | 2 | 191 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0.9 | 0 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | 0 | <1 | <1 | <1 |
| Calcium | ppm | ASTM D5185m | 0 | 3 | 1 | 4 |
| Phosphorus | ppm | ASTM D5185m | 409 | 194 | 184 | 18 |
| Zinc | ppm | ASTM D5185m | 0 | 10 | 3 | 123 |
| Sulfur | ppm | ASTM D5185m | 1290 | 756 | 665 | 256 |
| CONTAMINANTS | ; | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 2 | <1 | 1 |
| Sodium | ppm | ASTM D5185m | | 10 | 4 | 72 |
| Potassium | ppm | ASTM D5185m | >20 | 2 | <1 | 6 |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.537 | 0.63 | 0.53 | 1.50 |



OIL ANALYSIS REPORT





| VISUAL | | method | limit/base | current | history1 | history2 |
|-------------------------|--------|---------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| FLUID PROPERTIES | | method | limit/base | current | history1 | history2 |


| T LOID I HOI LITTILO | | | | | | | |
|----------------------|-----|-----------|-------|------|------|------|--|
| Visc @ 40°C | cSt | ASTM D445 | 44.56 | 43.9 | 42.3 | 43.4 | |


SAMPLE IMAGES


Color


Bottom















Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06154505 Lab Number : 06154505 Unique Number : 10989928

Received : 19 Apr 2024 **Tested** : 22 Apr 2024

Diagnosed : 23 Apr 2024 - Sean Felton

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

AIR HANDLING EQUIPMENT INC

Contact: ANGIE ROSENBECK

1389 RIVERSIDE DR SIDNEY, OH

US 45365

angie@ahequip.net

T: (937)658-6266 F: (937)492-3147

Report Id: UCAIRSID [WUSCAR] 06154505 (Generated: 04/23/2024 11:29:28) Rev: 1

Contact/Location: ANGIE ROSENBECK - UCAIRSID