



PROBLEM SUMMARY

Area ULTRA COOLANT Machine Id INGERSOLL RAND CBV683199 - FIRST SPEAR LLC Component Compressor



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC T	EST RES	SULTS			
Sample Status			SEVERE	SEVERE	
Acid Number (AN)	mg KOH/g	ASTM D8045	a 2.73	▲ 6.31	

Customer Id: UCJOHSAI Sample No.: JHF0000192 Lab Number: 06154545 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS					
Action	Status	Date	Done By	Description	
Change Fluid			?	Oil and filter change at the time of sampling has been noted.	
Flush System			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.	
Change Filter			?	Oil and filter change at the time of sampling has been noted.	

HISTORICAL DIAGNOSIS



02 Nov 2023 Diag: Angela Borella

Recommend drain oil if not already done and flush with cleaner before refilling with oil. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is above the recommended limit. TAN level indicates possible presence of varnish.







OIL ANALYSIS REPORT

Area ULTRA COOLANT Machine Id INGERSOLL RAND CBV683199 - FIRST SPEAR LLC Component

Component Compressor

DIAGNOSIS

Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is above the recommended limit. TAN level indicates possible presence of varnish.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		JHF0000192	UCH05999129	
Sample Date		Client Info		09 Apr 2024	02 Nov 2023	
Machine Age	hrs	Client Info		3753	3064	
Oil Age	hrs	Client Info		689	3064	
Oil Changed		Client Info		Not Changd	Changed	
Sample Status				SEVERE	SEVERE	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	12	39	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m		0	<1	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		<1	<1	
Aluminum	ppm	ASTM D5185m	>25	2	2	
Lead	ppm	ASTM D5185m	>25	<1	<1	
Copper	ppm	ASTM D5185m	>50	8	13	
Tin	ppm	ASTM D5185m	>15	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	2	20	
Barium	ppm	ASTM D5185m	500	715	426	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		2	7	
Magnesium	ppm	ASTM D5185m	0	2	6	
Calcium	ppm	ASTM D5185m	0	10	23	
Phosphorus	ppm	ASTM D5185m	20	0	16	
Zinc	ppm	ASTM D5185m	0	1006	567	
Sulfur	ppm	ASTM D5185m	200	266	247	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	2	
Sodium	ppm	ASTM D5185m		28	100	
Potassium	ppm	ASTM D5185m	>20	5	16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		2.73	6 .31	



OIL ANALYSIS REPORT

VISUAL





VISUAL				current		
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
Free Water	scalar	*Visual	20.1	NEG	NEG	
			limit/base			
		method ASTM D445	limit/base 49.4	current	history1	history2
Visc @ 40°C	cSt			54.5	58.1	
SAMPLE IMAGES	\$	method	limit/base	current	history1	history2
Color						no image
Bottom						no image
Ferrous Allovs						
iron chromium nickel	<u> </u>		Apd/24			
Non-ferrous Metals	5					
tion nickel	5		Apr9/24			
Non-ferrous Metals	5		Apr9/24 -	Acid Number		
Non-ferrous Metals	5		Apr9/24 -			
Non-ferrous Metals	5		Apr9/24 -			
Non-ferrous Metals	5		Apr9/24 -			
Non-ferrous Metals	5		Apr9/24 -			
Non-ferrous Metals	5		Acid Number (mg KDH/Q) 0°9 O'10 0°0 O'1	Severe Abnormal		
Non-ferrous Metals	5		Apr9/24 -			
Non-ferrous Metals	Madiso		b2/gudy b2/gud	Severe Abnoma		
Viscosity @ 40°C		ved : 19 d : 22	Apr3/24	Severe Abnormal Decomposition JOHN	4700 LEBOUR	

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Laboratory

Sample No.

Lab Number

Unique Number

Test Package :

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: RACHEL VON HATTEN - UCJOHSAI

rvonhatten@jhf.com T: (314)593-1267

F: (314)874-0965