




PROBLEM SUMMARY


Area
LFC-1030-CM-01-CM030 [1958017]
 Machine Id
ND01MT23-1030 - RECEIVING HOPPER
 Component
Gearbox
 Fluid
LE 4220 (--- GAL)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

▲ Ferrous Alloys



▲ Water (KF)



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	NORMAL
Iron	ppm	ASTM D5185m	>200	▲ 1025	189	130
Water	%	ASTM D6304	>0.2	▲ 0.983	---	---
ppm Water	ppm	ASTM D6304	>2000	▲ 9830	---	---
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	NEG	NEG

Customer Id: LEPALL
 Sample No.: WC0918543
 Lab Number: 06154556
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

NORMAL



20 Oct 2023 Diag: Wes Davis

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



19 Apr 2023 Diag: Don Baldrige

Resample at the next service interval to monitor. All component wear rates are normal. Iron noted. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



22 Oct 2022 Diag: Wes Davis

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



Area
LFC-1030-CM-01-CM030 [1958017]
 Machine Id
ND01MT23-1030 - RECEIVING HOPPER
 Component
Gearbox
 Fluid
LE 4220 (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

▲ Wear

The iron level is severe. Gear wear is indicated.

▲ Contamination

Appearance is hazy. There is a high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0918543	WC0851566	WC0793917
Sample Date	Client Info		15 Apr 2024	20 Oct 2023	19 Apr 2023
Machine Age	hrs	Client Info	180	0	0
Oil Age	hrs	Client Info	180	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	▲ 1025	189	130
Chromium	ppm	ASTM D5185m >15	3	1	<1
Nickel	ppm	ASTM D5185m >15	1	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >25	7	<1	<1
Lead	ppm	ASTM D5185m >100	<1	0	0
Copper	ppm	ASTM D5185m >200	4	4	<1
Tin	ppm	ASTM D5185m >25	0	<1	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	12	<1	3
Barium	ppm	ASTM D5185m	0	2	6
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	7	2	3
Magnesium	ppm	ASTM D5185m	3	0	5
Calcium	ppm	ASTM D5185m	17	3	6
Phosphorus	ppm	ASTM D5185m	281	269	332
Zinc	ppm	ASTM D5185m	140	55	57
Sulfur	ppm	ASTM D5185m	15534	7238	19264

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	23	9	11
Sodium	ppm	ASTM D5185m	22	2	3
Potassium	ppm	ASTM D5185m >20	4	0	0
Water	%	ASTM D6304 >0.2	▲ 0.983	---	---
ppm Water	ppm	ASTM D6304 >2000	▲ 9830	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.80	0.46	0.61




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	275	209	210

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0918543 **Received** : 19 Apr 2024
Lab Number : 06154556 **Tested** : 23 Apr 2024
Unique Number : 10989979 **Diagnosed** : 23 Apr 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF)

LEPRINO FOODS - ALLENDALE
 4700 RICH STREET
 ALLENDALE, MI
 US 49401
 Contact: BILL FERRIER
 BFERRIER@LEPRINOFOODS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)