




# OIL ANALYSIS REPORT



Machine Id  
**Brent Run CAT 4 BRRM04BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)**

Sample Rating Trend



**DIRT**



## DIAGNOSIS

### ▲ Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. ( Customer Sample Comment: 400 hr sample after head change )

### ▲ Wear

The tin level is abnormal. All other component wear rates are normal.

### ▲ Contamination

Elemental level of silicon (Si) above normal.

### ▲ Fluid Condition

The BN level is low. The AN level is acceptable for this fluid. The oil is no longer serviceable.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0915821</b>	WC0915825	WC0776719
Sample Date	Client Info		<b>17 Apr 2024</b>	10 Apr 2024	25 Mar 2024
Machine Age	hrs	Client Info	<b>107871</b>	107703	107350
Oil Age	hrs	Client Info	<b>471</b>	303	632
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status			<b>SEVERE</b>	ABNORMAL	SEVERE

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method		<b>NEG</b>	NEG	NEG
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >14	<b>4</b>	1	14
Chromium	ppm	ASTM D5185m >3	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >5	<b>2</b>	2	2
Lead	ppm	ASTM D5185m >8	<b>&lt;1</b>	2	1
Copper	ppm	ASTM D5185m >5	<b>2</b>	2	4
Tin	ppm	ASTM D5185m >3	<b>▲ 4</b>	<b>▲ 3</b>	4
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	2	8
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>2</b>	3	4
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>7</b>	6	10
Calcium	ppm	ASTM D5185m	<b>1861</b>	1855	1861
Phosphorus	ppm	ASTM D5185m	<b>281</b>	309	297
Zinc	ppm	ASTM D5185m	<b>307</b>	356	366
Sulfur	ppm	ASTM D5185m	<b>3205</b>	3205	3302

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >180	<b>▲ 211</b>	140	<b>▲ 217</b>
Sodium	ppm	ASTM D5185m >20	<b>3</b>	2	31
Potassium	ppm	ASTM D5185m >20	<b>0</b>	3	3

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	<b>6.4</b>	6.1	6.7
Sulfation	Abs/.1mm	*ASTM D7415	<b>23.3</b>	20.8	24.9


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	<b>16.8</b>	13.7	17.2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>2.945</b>	1.40	1.92
Base Number (BN)	mg KOH/g	ASTM D2896 5.4	<b>▲ 2.44</b>	3.17	2.98



# OIL ANALYSIS REPORT

## Non-ferrous Metals




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.7	13.5

## GRAPHS


## FT-IR (Direct Trend)




## Acid Number




## FT-IR (Direct Trend)




## Acid Number




## Iron (ppm)




## Aluminum (ppm)




## Copper (ppm)




## Viscosity @ 100°C




## Lead (ppm)




## Chromium (ppm)



## Silicon (ppm)



## Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0915821

Lab Number : 06154639

Unique Number : 10990062

Test Package : MOB 2

Received : 19 Apr 2024

Tested : 25 Apr 2024

Diagnosed : 25 Apr 2024 - Jonathan Hester

EDL NA Recips-Brent Run

Brent Run Power Station, 8383 Vienna Road

Montrose, MI

US 48457-9141

Contact: Rob Stewart

Rob.Stewart@energydevelopments.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)