




# FUEL REPORT

Sample Rating Trend



ISO



Machine Id  
**IDEM FO2T 12-13**

Component  
**Diesel Fuel**

Fluid  
**No.2 DIESEL FUEL (HIGH-SULPHUR) (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you filter this fluid before use if applicable. ASTM D240 result 17,929 BTU/lb. Test performed at subcontracted ISO 17025 laboratory. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel. Please note that this is a corrected copy for laboratory data update.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of silt (particulates < 14 microns in size) present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0934834</b>	WC0926732	WC0911759
Sample Date	Client Info			<b>15 Apr 2024</b>	15 Mar 2024	15 Feb 2024
Machine Age	hrs	Client Info		<b>0</b>	0	0
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	0.839	---	0.863	0.863
Specific Gravity		*ASTM D1298		<b>0.863</b>	0.863	---
Fuel Color	text	*Visual Screen	Yellow	<b>Red</b>	Red	Red
ASTM Color	scalar	*ASTM D1500		<b>L4.0</b>	L4.5	L4.5
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.76</b>	2.75	2.67
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	<b>67.5</b>	68.9	63
Cloud Point	°C	ASTM D5771		<b>-21</b>	-21	-21
Pour Point	°C	ASTM D5950		<b>-39</b>	-39	-38

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	500	<b>61</b>	24	23
Sulfur (UVF)	ppm	ASTM D5453		<b>38</b>	24	25






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	<b>178</b>	171	173
5% Distillation Point	°C	ASTM D86		<b>205</b>	198	198
10% Distill Point	°C	ASTM D86	201	<b>214</b>	211	211
15% Distillation Point	°C	ASTM D86		<b>222</b>	221	221
20% Distill Point	°C	ASTM D86	216	<b>229</b>	230	228
30% Distill Point	°C	ASTM D86	230	<b>243</b>	243	242
40% Distill Point	°C	ASTM D86	243	<b>255</b>	256	254
50% Distill Point	°C	ASTM D86	255	<b>266</b>	268	265
60% Distill Point	°C	ASTM D86	267	<b>278</b>	281	278
70% Distill Point	°C	ASTM D86	280	<b>290</b>	295	290
80% Distill Point	°C	ASTM D86	295	<b>303</b>	311	304
85% Distillation Point	°C	ASTM D86		<b>312</b>	321	312
90% Distill Point	°C	ASTM D86	310	<b>322</b>	338	323
95% Distillation Point	°C	ASTM D86		<b>337</b>	342	340
Final Boiling Point	°C	ASTM D86	341	<b>351</b>	345	352
Distillation Residue	%	ASTM D86	3.0	---	1.5	1.4
Distillation Loss	%	ASTM D86	3.0	---	4.3	0.5

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	<b>32</b>	32.5	32.5
Cetane Index		ASTM D4737	<40.0	<b>41</b>	42.6	41.6

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	0	0
Sodium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	2	<1
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	<1	<1
Water	%	ASTM D6304	<0.05	<b>0.005</b>	0.005	0.003
ppm Water	ppm	ASTM D6304	<500	<b>55</b>	53	39
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	0.0	0.0
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	0.0	0.0



# FUEL REPORT



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0934834  
**Lab Number** : 06155022  
**Unique Number** : 10990445  
**Test Package** : DF-3 ( Additional Tests: Fuel, Screen )  
**Received** : 19 Apr 2024  
**Tested** : 01 May 2024  
**Diagnosed** : 18 Jul 2024 - Doug Bogart

**PETROLEUM TECHNOLOGIES GROUP**  
 4665 BROADMOOR AVE, SUITE 150  
 GRAND RAPIDS, MI  
 US 49512  
 Contact: JAMES KRAFT  
 james@oil-lab.com  
 T: (616)698-9399  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 10595	▲ 9475	▲ 7984
Particles >6µm	ASTM D7647	>640	▲ 1686	▲ 1841	● 1102
Particles >14µm	ASTM D7647	>80	22	46	28
Particles >21µm	ASTM D7647	>20	3	8	6
Particles >38µm	ASTM D7647	>4	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 21/18/12	▲ 20/18/13	▲ 20/17/12

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	0
Nickel	ppm	ASTM D5185m <0.1	0	0	0
Lead	ppm	ASTM D5185m <0.1	0	0	0
Vanadium	ppm	ASTM D5185m <0.1	0	<1	0
Iron	ppm	ASTM D5185m <0.1	0	0	0
Calcium	ppm	ASTM D5185m <0.1	0	0	<1
Magnesium	ppm	ASTM D5185m <0.1	0	0	0
Phosphorus	ppm	ASTM D5185m <0.1	2	0	0
Zinc	ppm	ASTM D5185m <0.1	0	0	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					