




# OIL ANALYSIS REPORT

Sample Rating Trend



**DIRT**



Machine Id

**KAESER SX 6 3264478 (S/N 3541)**

Component

**Compressor**

Fluid

**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA012761</b>	KCP52313	KCP30136
Sample Date	Client Info	<b>15 Apr 2024</b>	01 May 2023	19 Apr 2021
Machine Age	hrs	<b>44718</b>	36485	22506
Oil Age	hrs	<b>8233</b>	28643	0
Oil Changed	Client Info	<b>Changed</b>	Changed	Not Changed
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<1	0	<1
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >10	2	0	<1
Lead	ppm	ASTM D5185m >10	<1	0	<1
Copper	ppm	ASTM D5185m >50	10	15	12
Tin	ppm	ASTM D5185m >10	<1	0	<1
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	0	0	11
Barium	ppm	ASTM D5185m 90	0	2	54
Molybdenum	ppm	ASTM D5185m 0	<1	0	0
Manganese	ppm	ASTM D5185m	0	0	<1
Magnesium	ppm	ASTM D5185m 100	1	2	65
Calcium	ppm	ASTM D5185m 0	0	0	5
Phosphorus	ppm	ASTM D5185m 0	2	0	3
Zinc	ppm	ASTM D5185m 0	0	0	3
Sulfur	ppm	ASTM D5185m 23500	18508	18723	19491

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	▲ 46	▲ 80	12
Sodium	ppm	ASTM D5185m	0	0	18
Potassium	ppm	ASTM D5185m >20	2	<1	1
Water	%	ASTM D6304 >0.05	0.003	0.001	0.028
ppm Water	ppm	ASTM D6304 >500	28	7.5	288.0






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	57151	4384	---
Particles >6µm	ASTM D7647 >1300	▲ 15098	904	---
Particles >14µm	ASTM D7647 >80	▲ 1068	58	---
Particles >21µm	ASTM D7647 >20	▲ 266	15	---
Particles >38µm	ASTM D7647 >4	▲ 7	0	---
Particles >71µm	ASTM D7647 >3	0	0	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 23/21/17	19/17/13	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.58	0.54	0.442

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	50.8	48.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA012761 **Received** : 19 Apr 2024  
**Lab Number** : 06155194 **Tested** : 24 Apr 2024  
**Unique Number** : 10990617 **Diagnosed** : 24 Apr 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**OLD DOMINION FREIGHT LINES**  
 200 INDEPENDENCE AVE  
 LOCKWOOD, NV  
 US 89434  
 Contact: JEFF JONES  
 jeff.jones@odfl.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)