

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

9048132 (S/N NOT GIVEN)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			0ct2023	Apr2024		
SAMPLE INFORM	NOITAN	method				history2
Sample Number		Client Info		KC130667	KCPA009144	
Sample Date		Client Info		11 Apr 2024	30 Oct 2023	
Machine Age	hrs	Client Info		7990	4057	
Oil Age	hrs	Client Info		7000	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	8	
Lead	ppm	ASTM D5185m	>10	- <1	0	
Copper	ppm	ASTM D5185m	>50	3	0	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium		ASTM D5185m	90	0	20	
Molybdenum	ppm	ASTM D5185m	90	<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	<1	9	
Calcium	ppm	ASTM D5185m		0	0	
	ppm		2	14	27	
Phosphorus	ppm	ASTM D5185m		0	50	
Zinc	ppm	ASTM D5185m				
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	
Sodium	ppm	ASTM D5185m		0	7	
Potassium	ppm	ASTM D5185m	>20	1	4	
Water	%	ASTM D6304	>0.05	0.003	0.008	
ppm Water	ppm	ASTM D6304	>500	26	81.1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1272	10191	
Particles >6µm		ASTM D7647	>1300	433	1852	
Particles >14μm		ASTM D7647	>80	19	29	
Particles >21µm		ASTM D7647	>20	4	3	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/11	21/18/12	
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
A stat Nicosale and (ANI)		AOTH Doors	0.4		0.04	

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.34

0.46



OIL ANALYSIS REPORT







Certificate 12367

Sample No. Lab Number

: KC130667 : 06155195 Unique Number : 10990618 Test Package : IND 2

Received : 19 Apr 2024 **Tested** : 24 Apr 2024

Diagnosed : 24 Apr 2024 - Jonathan Hester 111 BUSINESS PARK DR UTICA, NY US 13502

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: