


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 9194322 (S/N 2174) Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

## Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan2024	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC123242	KC123267	
Sample Date		Client Info		01 Apr 2024	17 Jan 2024	
Machine Age	hrs	Client Info		2222	1112	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	4	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	<1	<1	
Copper	ppm	ASTM D5185m	>50	13	5	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	16	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	13	45	
Calcium	ppm	ASTM D5185m	2	0	2	
Phosphorus	ppm	ASTM D5185m		6	<1	
Zinc	ppm	ASTM D5185m		28	9	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		0	6	
Potassium	ppm	ASTM D5185m	>20	6	16	
Water	%	ASTM D6304	>0.05	0.013	0.023	
ppm Water	ppm	ASTM D6304	>500	136	239	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		101368	7277	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 39119	<b>△</b> 2697	
Particles >14µm		ASTM D7647	>80	<u>▲</u> 3135	<b>293</b>	
Particles >21µm		ASTM D7647	>20	<u> </u>	<b>▲</b> 86	
Particles >38µm		ASTM D7647	>4	<u> </u>	3	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>4</u> 24/22/19	<u>^</u> 20/19/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A atal Niconala a v. (ANI)	1/011/	4 OT1 4 D00 45	0.1		0.04	

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.31

0.33



# **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

: KC123242 Lab Number : 06155206 Unique Number : 10990629 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 19 Apr 2024

Tested : 24 Apr 2024 Diagnosed : 24 Apr 2024 - Jonathan Hester 3740 KENDALL RD CAPE HAZE, FL US 33946

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: