

OIL ANALYSIS REPORT

Area [20590650] 810-M5050 Component Gearbox

ROYAL PURPLE POLYGUARD FDA 220 (--- GAL)

Sample Rating Trend



DIAGNOSIS	SAMPLE INFORM	IATION	method				history2
Recommendation	Sample Number		Client Info		WC0904636	WC0819225	WC0805845
Resample at the next service interval to monitor.	Sample Date		Client Info		10 Apr 2024	23 Oct 2023	24 Apr 2023
Wear	Machine Age	mths	Client Info		0	0	0
All component wear rates are normal.	Oil Age	mths	Client Info		0	0	0
Contamination	Oil Changed		Client Info		Not Changd	N/A	Not Changd
There is no indication of any contamination in the	Sample Status				NORMAL	NORMAL	NORMAL
oil.	CONTAMINATION	1	method	limit/base	current	history1	history2
Fluid Condition The AN level is acceptable for this fluid. The	Water		WC Method	>0.2	NEG	NEG	NEG
condition of the oil is suitable for further service.	WEAR METALS		method				history2


Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	9	2	1
Chromium	ppm	ASTM D5185m	>15	<1	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	0	<1
Lead	ppm	ASTM D5185m	>100	<1	0	0
Copper	ppm	ASTM D5185m	>200	<1	0	0
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2


ADDITIVES		memou	IIIIIII Dasc	Current	Thistory i	Thistory 2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		4	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		<1	0	1
Calcium	ppm	ASTM D5185m		12	0	<1
Phosphorus	ppm	ASTM D5185m		485	473	514
Zinc	ppm	ASTM D5185m		5	0	5
Sulfur	ppm	ASTM D5185m		119	0	255
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	8	5	2
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	nnm	ΔSTM D5185m	>20	2	0	Λ

Folassium	ррпп	ASTIVI DS TOSIII	>20	2	U	U
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.86	1.61	1.70



OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIFS	method	limit/base	current	history1	history2

Visc @ 40°C	cSt	ASTM D445	222	221	222


SAMPLE IMAGES


Color


Bottom


















Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0904636 Lab Number : 06155217 Unique Number : 10990640 Test Package : IND 2

Received **Tested** Diagnosed

: 19 Apr 2024 : 23 Apr 2024 : 24 Apr 2024 - Jonathan Hester

THERMO FISHER 6173 East Old Marion Highway, Bldg. 806

Florence, SC US 29506 Contact: BARRY OLIVER

Calvin.Oliver@Roche.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (843)629-4577 F: (843)629-4553

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: ROCFLO [WUSCAR] 06155217 (Generated: 04/24/2024 13:11:03) Rev: 1

Contact/Location: BARRY OLIVER - ROCFLO