

OIL ANALYSIS REPORT

Area [20590651] 810-M5060

Component **Gearbox**

ROYAL PURPLE POLYGUARD FDA 220 (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0904637	WC0805837	WC0805847
Sample Date		Client Info		10 Apr 2024	23 Oct 2023	24 Apr 2023
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	28	3	21
Chromium	ppm	ASTM D5185m	>15	<1	0	<1
Nickel	ppm	ASTM D5185m	>15	<1	0	<1
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<u>^</u> 28	0	22
Lead	ppm	ASTM D5185m	>100	<1	0	0
Copper	ppm	ASTM D5185m	>200	<1	0	0
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		<1	0	1
Calcium	ppm	ASTM D5185m		28	0	36
Phosphorus	ppm	ASTM D5185m		453	443	503
Zinc	ppm	ASTM D5185m		104	0	91
Sulfur	ppm	ASTM D5185m		629	980	799
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	20	4	16
Sodium	ppm	ASTM D5185m		<1	7	3
Potassium	ppm	ASTM D5185m	>20	2	0	1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.52	1.37	1.48



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		mathad	limit/hooo	ou urrount	hiotomyt	hiotom (O
FLUID PROPERTIES		method	limit/base	current	history1	history2

Visc @ 40°C	cSt	ASTM D445		219	214	219
SAMPLE IMAG	GES	method	limit/base	current	history1	history2


Color








GRAPHS

Ferrous Alloys













Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06155221 Unique Number : 10990644

: WC0904637

Received : 19 Apr 2024 **Tested** : 23 Apr 2024 Diagnosed

THERMO FISHER 6173 East Old Marion Highway, Bldg. 806 Florence, SC US 29506

: 24 Apr 2024 - Don Baldridge

Contact: BARRY OLIVER Calvin.Oliver@Roche.com T: (843)629-4577

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: ROCFLO [WUSCAR] 06155221 (Generated: 04/24/2024 13:01:15) Rev: 1

Contact/Location: BARRY OLIVER - ROCFLO

F: (843)629-4553