


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 3

1 Screw Compressor

ROYAL PURPLE Polyguard FDA ISO 46 (---

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: From the screw.)

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.

GAL)				Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0891438		
Sample Date		Client Info		10 Apr 2024		
Machine Age	hrs	Client Info		26062		
Oil Age	hrs	Client Info		4000		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>60	0		
Chromium	ppm	ASTM D5185m	>4	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>5	3		
_ead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>30	8		
Γin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		<u> </u>		
Zinc	ppm	ASTM D5185m		<u> </u>		
Sulfur	ppm	ASTM D5185m		165		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	0		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
Nater	%	ASTM D6304	>0.1	0.010		
opm Water	ppm	ASTM D6304	>1000	101		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	28335		
Particles >6µm		ASTM D7647	>2500	^ 7680		
Particles >14µm		ASTM D7647	>320	<u>▲</u> 681		
Particles >21µm		ASTM D7647	>80	<u>^</u> 201		
Particles >38µm		ASTM D7647	>20	6		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>22/20/17</u>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.45		



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: WC0891438 Lab Number : 06155893 Unique Number : 10991316 Test Package : PLANT

Received : 22 Apr 2024 **Tested** : 23 Apr 2024 Diagnosed

: 24 Apr 2024 - Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: JASON VIBBERT JASON.VIBBERT@DART.BIZ T:

1545 HOUSTON RD

BURLESON, TX

F: (817)447-0970

US 76028

Report Id: TEXBURTX [WUSCAR] 06155893 (Generated: 04/24/2024 13:22:51) Rev: 1

Submitted By: JASON VIBBERT