


# OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Machine Id  
**SUMMIT SE HT 7**  
 Component  
**Heat Transfer Fluid**  
 Fluid  
**{not provided} (--- GAL)**

**DIAGNOSIS**

**▲ Recommendation**  
 We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. We were unable to perform a particle count due to a high concentration of particles present in this sample.

**Wear**  
 All component wear rates are normal.

**▲ Contamination**  
 There is a moderate amount of visible silt present in the sample.

**Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

**SAMPLE INFORMATION**    method    limit/base    current    history1    history2

Sample Number	Client Info		<b>TO10003235</b>	---	---
Sample Date	Client Info		<b>17 Apr 2024</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed		Client Info	<b>N/A</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

**WEAR METALS**    method    limit/base    current    history1    history2

Iron	ppm	ASTM D5185m	>200	<b>0</b>	---	---
Chromium	ppm	ASTM D5185m	>21	<b>0</b>	---	---
Nickel	ppm	ASTM D5185m	>21	<b>1</b>	---	---
Titanium	ppm	ASTM D5185m	>21	<b>&lt;1</b>	---	---
Silver	ppm	ASTM D5185m	>21	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m	>21	<b>0</b>	---	---
Lead	ppm	ASTM D5185m	>21	<b>0</b>	---	---
Copper	ppm	ASTM D5185m	>21	<b>&lt;1</b>	---	---
Tin	ppm	ASTM D5185m	>21	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m		<b>4</b>	---	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	---	---

**ADDITIVES**    method    limit/base    current    history1    history2

Boron	ppm	ASTM D5185m		<b>0</b>	---	---
Barium	ppm	ASTM D5185m		<b>0</b>	---	---
Molybdenum	ppm	ASTM D5185m		<b>0</b>	---	---
Manganese	ppm	ASTM D5185m		<b>0</b>	---	---
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	---	---
Calcium	ppm	ASTM D5185m		<b>0</b>	---	---
Phosphorus	ppm	ASTM D5185m		<b>0</b>	---	---
Zinc	ppm	ASTM D5185m		<b>0</b>	---	---
Sulfur	ppm	ASTM D5185m		<b>9524</b>	---	---





**CONTAMINANTS**    method    limit/base    current    history1    history2

Silicon	ppm	ASTM D5185m	>25	<b>7</b>	---	---
Sodium	ppm	ASTM D5185m	>21	<b>0</b>	---	---
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	---	---
Water	%	ASTM D6304	>0.0601	<b>0.033</b>	---	---
ppm Water	ppm	ASTM D6304	>601	<b>330</b>	---	---

**FLUID DEGRADATION**    method    limit/base    current    history1    history2



Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.65</b>	---	---
------------------	----------	------------	--	-------------	-----	-----

# OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.0601	0.2%	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	498	---	---
Visc @ 100°C	cSt	ASTM D445	50.0	---	---
Viscosity Index (VI)	Scale	ASTM D2270	160	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO10003235 **Received** : 22 Apr 2024  
**Lab Number** : 06155929 **Tested** : 24 Apr 2024  
**Unique Number** : 10991352 **Diagnosed** : 24 Apr 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**TULCO OILS INC (001-TULSA DIVISION)**  
 5240 EAST PINE  
 TULSA, OK  
 US 74115  
 Contact: DYLAN COPE  
 dylancope@tulco.com  
 T: (800)375-2347  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)