

## **OIL ANALYSIS REPORT**

Sample Rating Trend



#### Machine Id

# **INGERSOLL RAND COMPRESSOR 5**

Air Compressor Fluid

INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		TO50000994	TO5000746		
Sample Date		Client Info		17 Apr 2024	23 Jul 2019		
Machine Age	hrs	Client Info		30066	0		
Oil Age	hrs	Client Info		0	0		
Oil Changed		Client Info		N/A	N/A		
Sample Status				NORMAL	NORMAL		
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	<1		
Chromium	ppm	ASTM D5185m	>4	0	0		
Nickel	ppm	ASTM D5185m	>4	0	0		
Titanium	ppm	ASTM D5185m		<1	0		
Silver	ppm	ASTM D5185m		0	0		
Aluminum	ppm	ASTM D5185m	>10	0	<1		
Lead	ppm	ASTM D5185m	>20	0	<1		
Copper	ppm	ASTM D5185m	>40	<1	<1		
Tin	ppm	ASTM D5185m	>5	1	0		
Antimony	ppm	ASTM D5185m			0		
Vanadium	ppm	ASTM D5185m		<1	0		
Cadmium	ppm	ASTM D5185m		0	0		
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	3		
Barium	ppm	ASTM D5185m	500	511	699		
Molybdenum	ppm	ASTM D5185m	0	0	0		
Manganese	ppm	ASTM D5185m	Ū	0	<1		
Magnesium	ppm	ASTM D5185m	0	2	<1		
Calcium	ppm		0	10	3		
Phosphorus	ppm	ASTM D5185m	20	9	7		
Zinc	ppm		0	118	66		
Sulfur	ppm	ASTM D5185m	200	377	271		
CONTAMINANTS		method	limit/base	current	history1	history2	
					,	,	
Silicon	ppm	ASTM D5185m	>25	4	5		
Sodium	ppm	ASTM D5185m	00	7	8		
Potassium	ppm	ASTM D5185m		1	2		
Water ppm Water	%	ASTM D6304 ASTM D6304		0.292 2922	0.322 3220		
	ppm						
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>10000	1077	4313		
Particles >6µm		ASTM D7647 ASTM D7647		64	443 28		
Particles >14µm			>320	9 4			
Particles >21µm		ASTM D7647		4	8		
Particles >38µm		ASTM D7647	>20	0	0		
Particles >71µm Oil Cleanliness		ASTM D7647 ISO 4406 (c)	>4 >20/18/15	0 17/13/10	0 19/16/12		
FLUID DEGRADA		method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.399 0.222 Contact/Location: KENNY CLARK - DAL PLATO				


Report Id: DALPLATO [WUSCAR] 06155933 (Generated: 04/24/2024 18:04:57) Rev: 1

Contact/Location: KENNY CLARK - DALPLATO



# **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
visc @ 40°C	cSt	ASTM D445	49.4	51.9	51.3	
Visc @ 100°C	cSt	ASTM D445		9.2	9.3	
Viscosity Index (VI)	Scale	ASTM D2270	161	160	165	
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
				8" M		
Color				•		no image
Bottom						no image
GRAPHS						
Ferrous Alloys				Particle Count		
T			491,52	<sup>0</sup> T		T <sup>26</sup>
iron chromium			122,88	0-Severe		-24
nickel						
2			30,72	Abnormal		-22
5 S			₹ € 7,68			-20
Jul23/1			Apr17/24 (per 1 ml	0	• E	-18
-			Ap des (p			10
Non-ferrous Metals	5		Apr17/24 48 150 170 172 172 172 172 172 172 172 172 172 172			+20 -18 -16 -14
copper			ing 12	-		-14
sessesses lead						
			3			+12
1				8 -		-10
3/19			7/24	2-		-8
Jul23/19			Apr17/24	0.		
Viscosity @ 40°C				4μ 6μ	14µ 21µ	38µ 71µ
Severe			\$2.5	Acid Number		
Abnormal			HOX 2.0	0 Severe		
- Baarmal			ຍັ 1.5 ໂຄ	Abnormal		
		*****	- 41.0	0		
Severe			()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000 ()(10,000)			
- 6 L/SZInC			Apr17/24 -	Jul23/19 -		N CL L
VearCheck USA - 501 O50000994 <mark>6155933</mark> 0991356	Rece Teste	ived : 22 d : 23		than Hester		PRNING NEW PLANO PKW PLANO, T US 7507
D 2 (Additional Test	ts: KF, K	V100, PrtCo	unt, VI)			ENNY CLAR

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: DALPLATO [WUSCAR] 06155933 (Generated: 04/24/2024 18:04:57) Rev: 1

Certificate L2367

Laboratory Sample No. Lab Number Unique Number Test Package

Contact/Location: KENNY CLARK - DALPLATO

kclark@dallasnews.com

T: (214)977-6929

F: (214)977-6888