


OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
Thermoforming
 Machine Id
Line 10 C Extruder (S/N AN618)
 Component
Bevel Helical Gearbox
 Fluid
{not provided} (78 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50002284	TO50002199	TO50001534
Sample Date	Client Info	17 Apr 2024	26 Feb 2024	15 Nov 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	Not Changed	Not Changed	Not Changed
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	18	14	12	
Iron	ppm	ASTM D5185m >150	17	16	12
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m >10	0	0	<1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	0	<1
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >50	<1	<1	1
Tin	ppm	ASTM D5185m >10	0	0	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	1	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	<1
Calcium	ppm	ASTM D5185m	2	2	5
Phosphorus	ppm	ASTM D5185m	577	614	645
Zinc	ppm	ASTM D5185m	7	0	10
Sulfur	ppm	ASTM D5185m	656	623	612

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	38	▲ 140	▲ 56
Sodium	ppm	ASTM D5185m	2	3	3
Potassium	ppm	ASTM D5185m >20	0	0	0
Water	%	ASTM D6304 >0.1	0.007	0.003	0.002
ppm Water	ppm	ASTM D6304 >1000	79	35	24.1

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	▲ 7114	▲ 2772	▲ 2824
Particles >6µm	ASTM D7647 >320	▲ 2432	▲ 739	▲ 765
Particles >14µm	ASTM D7647 >80	▲ 189	62	60
Particles >21µm	ASTM D7647 >20	▲ 60	18	18
Particles >38µm	ASTM D7647 >4	▲ 7	1	2
Particles >71µm	ASTM D7647 >3	▲ 1	0	1
Oil Cleanliness	ISO 4406 (c) >17/15/13	▲ 20/18/15	▲ 19/17/13	▲ 19/17/13

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.74	0.73	0.60

OIL ANALYSIS REPORT


▲ Particle Trend




Water (KF)




PQ



Viscosity @ 100°C



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	173	178	173
Visc @ 100°C	cSt	ASTM D445	17.0	17.1	17.2
Viscosity Index (VI)	Scale	ASTM D2270	104	102	106

SAMPLE IMAGES

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : TO50002284

Lab Number : 06155944

Unique Number : 10991367

Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)

Received : 22 Apr 2024

Tested : 23 Apr 2024

Diagnosed : 24 Apr 2024 - Don Baldrige

DART CONTAINER CORPORATION

4444 W LEADBETTER DR

DALLAS, TX

US 75236

Contact: YON PALOMINO

yon.palomino@dart.biz

T: (214)775-5673

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)