


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 8036055

Component Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ap	Ź023	Aug2023 Apr202	7	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016806	KCPA006729	KCP53584
Sample Date		Client Info		10 Apr 2024	16 Aug 2023	03 Apr 2023
Machine Age	hrs	Client Info		7956	5120	2925
Oil Age	hrs	Client Info		2836	0	2925
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	7	5	4
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	4	7
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	4	1	7
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		2	4	6
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	440	469	307
Zinc	ppm	ASTM D5185m		115	38	86
Sulfur	ppm	ASTM D5185m		2168	2532	7302
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		0	<1	1
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.05	0.003	0.004	0.005
ppm Water	ppm	ASTM D6304	>500	35	42.3	51.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1878	1015	2263
Particles >6μm		ASTM D7647	>1300	565	451	1085
Particles >14µm		ASTM D7647	>80	40	26	57
Particles >21µm		ASTM D7647	>20	9	4	8
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	17/16/12	18/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	1.54	1.27	0.99



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA016806 : 06155956 Unique Number: 10991379

Received **Tested** Diagnosed : 22 Apr 2024

: 23 Apr 2024

: 24 Apr 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. **KROGER CENTRAL FILL**

301 LOGISTICS AVE JEFFERSONVILLE, IN US 47130

Contact: REBECCA WILLIAMSON rebecca.williamson@kroger.com

T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: