

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

GOODYEAR AKRON TEST 90

Hydraulic System

CONOCO MEGAFLOW AW 46 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan 2023	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	hictory?
	IATION		IIIIIIVDase		history1	history2
Sample Number		Client Info		ST46140	ST44353	
Sample Date		Client Info		21 Apr 2024	02 Jan 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	2	1	
Chromium	ppm	ASTM D5185m	>20	<1	0	
Nickel	ppm	ASTM D5185m	>20	<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	2	0	
Lead	ppm	ASTM D5185m	>20	<1	0	
Copper	ppm	ASTM D5185m	>20	18	<u>^</u> 20	
Tin	ppm	ASTM D5185m	>20	<1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		<1	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		<1	0	
Calcium	ppm	ASTM D5185m		23	14	
Phosphorus	ppm	ASTM D5185m		345	278	
Zinc	ppm	ASTM D5185m		342	245	
Sulfur	ppm	ASTM D5185m		845	775	
CONTAMINANTS		method	limit/base	current	history1	history2
						HISTOLYZ
Silicon	ppm	ASTM D5185m	>15	2	<1	
Sodium	ppm	ASTM D5185m		1	2	
Potassium	ppm	ASTM D5185m		1	0	
Water	%	ASTM D6304	>0.05	0.00	0.006	
ppm Water	ppm	ASTM D6304	>500	0	68.1	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>640	169	<u>▲</u> 1724	
Particles >6µm		ASTM D7647	>160	31	<u></u> 719	
Particles >14μm		ASTM D7647	>20	6	<u>^</u> 70	
Particles >21µm		ASTM D7647	>4	3	<u>^</u> 21	
Particles >38μm		ASTM D7647	>3	0	2	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>16/14/11	15/12/10	▲ 18/17/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.38	0.32	0.29	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: ST46140 Lab Number : 06155984 Unique Number : 10991407

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Apr 2024 **Tested**

: 23 Apr 2024 Diagnosed : 24 Apr 2024 - Jonathan Hester

Test Package : IND 2 (Additional Tests: KF) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FLUID POWER SOLUTIONS

4400 Edgewyn Ave. Hilliard, OH US 43026

Contact: SCOTT ROGERS

srogers@fluid-power-solutions.com T: (614)777-8954

F: (614)777-8640

Contact/Location: SCOTT ROGERS - FLUHIL