


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

GOODYEAR AKRON TEST 52

Hydraulic System

PHILLIPS 66 Powerflow NZ AW46 (--- GAL)

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan 2023	Apr2024		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number	VII/ (11101)	Client Info	mmubase	ST46272	ST44225	motoryz
Sample Date		Client Info		21 Apr 2024	02 Jan 2023	
Machine Age	hrs	Client Info		0	02 3411 2023	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1115	Client Info		N/A	N/A	
Sample Status		Ciletit IIIIO		ATTENTION	ATTENTION	
•						
WEAR METALS		method	limit/base		history1	history2
ron	ppm	ASTM D5185m	>20	1	<1	
Chromium	ppm	ASTM D5185m	>20	<1	0	
Nickel	ppm	ASTM D5185m	>20	<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	2	0	
Lead	ppm	ASTM D5185m	>20	0	0	
Copper	ppm	ASTM D5185m	>20	6	5	
Tin	ppm	ASTM D5185m	>20	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		<1	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		<1	0	
Calcium	ppm	ASTM D5185m		44	33	
Phosphorus	ppm	ASTM D5185m		477	406	
Zinc	ppm	ASTM D5185m		518	408	
Sulfur	ppm	ASTM D5185m		1322	1270	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	<1	
Sodium	ppm	ASTM D5185m		2	3	
Potassium	ppm	ASTM D5185m	>20	2	0	
Water	%	ASTM D6304	>0.05	0.004	0.017	
opm Water	ppm	ASTM D6304	>500	46	170.2	
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>640	150	1166	
Particles >6µm		ASTM D7647	>160	39	316	
Particles >14µm		ASTM D7647	>20	12	12	
Particles >21µm		ASTM D7647	>4	7	5	
Particles >38µm		ASTM D7647	>3	1	1	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>16/14/11	14/12/11	17/15/11	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.22	0.50	0.51	

Contact/Location: SCOTT ROGERS - FLUHIL



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : ST46272 Lab Number : 06155997

Tested Diagnosed Unique Number : 10991420

Received

: 22 Apr 2024

: 23 Apr 2024

: 23 Apr 2024 - Wes Davis

Test Package : IND 2 (Additional Tests: KF) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FLUID POWER SOLUTIONS

4400 Edgewyn Ave. Hilliard, OH US 43026

Contact: SCOTT ROGERS srogers@fluid-power-solutions.com

> T: (614)777-8954 F: (614)777-8640