




# PROBLEM SUMMARY

Area  
**BAGLINE**  
Machine Id  
**KETTLE 6 - BAG**

Component  
**Bottom Refrigeration Compressor**  
Fluid  
**PETRO CANADA PURITY FG SYNTH EP GEAR 220 (--- GAL)**

Sample Rating Trend




**WATER**




## COMPONENT CONDITION SUMMARY

▲ Water (KF)



▲ Ferrous Alloys



## RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>8	▲ 77	▲ 45	27
Water	%	ASTM D6304	>0.01	▲ 0.081	0.004	0.011
ppm Water	ppm	ASTM D6304	>100	▲ 810	41	116.0
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Emulsified Water	scalar	*Visual	>0.01	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual		▲ >10%	NEG	NEG

Customer Id: KRACED  
Sample No.: USP0006492  
Lab Number: 06156017  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

DIRT



### 17 Dec 2023 Diag: Doug Bogart

Resample at the next service interval. The iron level is abnormal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



DIRT



### 10 Oct 2023 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



DIRT



### 29 Jun 2023 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area

**BAGLINE**

Machine Id

**KETTLE 6 - BAG**

Component

**Bottom Refrigeration Compressor**

Fluid

**PETRO CANADA PURITY FG SYNTH EP GEAR 220 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### ▲ Wear

The iron level is abnormal.

### ▲ Contamination

Moderate concentration of visible dirt/debris present in the oil. Excessive free water present. There is a light concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USP0006492</b>	USP0004459	USP0001374
Sample Date	Client Info		<b>21 Apr 2024</b>	17 Dec 2023	10 Oct 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>▲ 77</b>	▲ 45	27
Chromium	ppm	ASTM D5185m >2	<b>1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >3	<b>2</b>	1	1
Lead	ppm	ASTM D5185m >2	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >8	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185m >4	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>2</b>	0	2
Calcium	ppm	ASTM D5185m	<b>9</b>	0	14
Phosphorus	ppm	ASTM D5185m	<b>550</b>	568	547
Zinc	ppm	ASTM D5185m	<b>5</b>	0	2
Sulfur	ppm	ASTM D5185m	<b>424</b>	537	825

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>24</b>	▲ 56	▲ 71
Sodium	ppm	ASTM D5185m	<b>3</b>	3	2
Potassium	ppm	ASTM D5185m >20	<b>1</b>	0	0
Water	%	ASTM D6304 >0.01	<b>▲ 0.081</b>	0.004	0.011
ppm Water	ppm	ASTM D6304 >100	<b>▲ 810</b>	41	116.0

## FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	---	▲ 99733	▲ 76814
Particles >6µm	ASTM D7647	>2500	---	▲ 9973	▲ 5402
Particles >14µm	ASTM D7647	>640	---	38	34
Particles >21µm	ASTM D7647	>160	---	10	8
Particles >38µm	ASTM D7647	>40	---	6	1
Particles >71µm	ASTM D7647	>10	---	2	0
Oil Cleanliness	ISO 4406 (c)	>20/18/16	---	▲ 24/20/12	▲ 23/20/12

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.59	<b>1.01</b>	0.38	0.42



# OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual	>10%	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 221	229	215	211

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USP0006492      **Received** : 22 Apr 2024  
**Lab Number** : 06156017      **Tested** : 24 Apr 2024  
**Unique Number** : 10991440      **Diagnosed** : 24 Apr 2024 - Jonathan Hester  
**Test Package** : IND 2

**KraftHeinz - Cedar Rapids - Plant 8370**  
 4601 C ST SW  
 CEDAR RAPIDS, IA  
 US 52404  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)