


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

C1102A (S/N 960231A)

Component Compressor

CHEVRON CETUS PAO ISO 100 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Feb 2024	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0006373	USP0007558	
Sample Date		Client Info		15 Apr 2024	22 Feb 2024	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	4	5	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m		<1	<1	
Titanium	ppm	ASTM D5185m		<1	<1	
Silver	ppm	ASTM D5185m		<1	0	
Aluminum	ppm	ASTM D5185m	>25	2	<1	
Lead	ppm	ASTM D5185m	>25		0	
Copper	ppm	ASTM D5185m		2	2	
Tin	ppm	ASTM D5185m	>15	<1	<1	
Vanadium	ppm	ASTM D5185m	>10	<1	0	
Cadmium		ASTM D5185m		<1	<1	
	ppm					
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		<1	0	
Molybdenum	ppm	ASTM D5185m		<1	<1	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		<1	<1	
Calcium	ppm	ASTM D5185m		<1	0	
Phosphorus	ppm	ASTM D5185m		453	456	
Zinc	ppm	ASTM D5185m		1	0	
Sulfur	ppm	ASTM D5185m		2377	2467	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	2	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	1	<1	
Water	%	ASTM D6304	>0.1	0.00	0.001	
ppm Water	ppm	ASTM D6304	>1000	0	7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1464	4727	
Particles >6µm		ASTM D7647	>2500	395	1016	
Particles >14µm		ASTM D7647	>320	22	42	
Particles >21µm		ASTM D7647	>80	4	11	
Particles >38µm		ASTM D7647	>20	0	0	
Particles >71µm		ASTM D7647	>4	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/12	19/17/13	
FLUID DEGRADA	TION_	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.103	0.101	
. Sid Hallibol (All)	y IVOIIIY	. 10 . IVI DUUTU		3.100	0.101	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06156024 Unique Number : 10991447

: USP0006373

Test Package : IND 2

Received : 22 Apr 2024 **Tested** : 23 Apr 2024

Diagnosed : 24 Apr 2024 - Jonathan Hester **REC SILICON MATERIALS** 119140 RICK JONES WAY

SILVER BOW, MT US 59750

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: RECSIL USP [WUSCAR] 06156024 (Generated: 04/24/2024 07:44:06) Rev: 1

Contact/Location: Service Manager - RECSIL_USP

T:

F: