


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

BITZER 75L C2 (S/N 1096301220)

Compressor

BVA4214-320 (3 GAL)

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0933635	WC0436494	
Sample Date		Client Info		16 Apr 2024	15 May 2020	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ATTENTION	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	26	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m		<1	<1	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	2	0	
Lead	ppm	ASTM D5185m	>25	0	1	
Copper	ppm	ASTM D5185m	>50	2	2	
Tin	ppm	ASTM D5185m	>15	2	<1	
Antimony	ppm	ASTM D5185m			2	
Vanadium	ppm	ASTM D5185m		<1	<1	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	1	
Barium	ppm	ASTM D5185m		<1	<1	
Molybdenum	ppm	ASTM D5185m		<1	1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		<1	0	
Calcium	ppm	ASTM D5185m		<1	<1	
Phosphorus	ppm	ASTM D5185m		3	2	
Zinc	ppm	ASTM D5185m		2	0	
Sulfur	ppm	ASTM D5185m		0	32	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	11	2	
Sodium	ppm	ASTM D5185m		1	<1	
Potassium	ppm	ASTM D5185m	>20	1	<1	
Water	%	ASTM D6304	>0.1	0.00	0.032	
ppm Water	ppm	ASTM D6304	>1000	0	329.5	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.042	0.091	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory

Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0933635 Lab Number : 06156081

Unique Number : 10991504

Received **Tested** Diagnosed

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: 24 Apr 2024 - Jonathan Hester

: 22 Apr 2024

: 23 Apr 2024

BRANCHBURG, NJ US 08876 Contact: LARRY DELGUERCIO larry@commairsystems.com

COMMERCIAL AIR SYSTEMS

T: (908)927-9090 F: (908)921-9091

10 COUNTY LINE RD

Report Id: COMBRANJ [WUSCAR] 06156081 (Generated: 04/24/2024 17:15:52) Rev: 1

Contact/Location: LARRY DELGUERCIO - COMBRANJ