


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id 01Y607 Component Gearbox

ROYAL PURPLE SYNFILM 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


	3m2014 Fm2017 Jun2017 Jun2018 Mm2019 Jun2021 Mm ₂ 0223 App2024							
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2		
Sample Number	17111011	Client Info	mmbasc	RP0037809	RP0035968	RP0033438		
Sample Date		Client Info		21 Apr 2024	07 Aug 2023	11 May 2023		
Machine Age	hrs	Client Info		0	07 Aug 2023	0		
Oil Age	hrs	Client Info		0	0	0		
Oil Changed	1113	Client Info		N/A	N/A	N/A		
Sample Status		Oliciti IIIIo		NORMAL	NORMAL	ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185m	>200	<1	0	2		
Chromium	ppm	ASTM D5185m	>15	<1	0	0		
Nickel	ppm	ASTM D5185m	>15	<1	<1	<1		
Titanium	ppm	ASTM D5185m		<1	<1	0		
Silver	ppm	ASTM D5185m		0	<1	0		
Aluminum	ppm	ASTM D5185m	>25	2	<1	<1		
Lead	ppm	ASTM D5185m	>100	0	<1	0		
Copper	ppm	ASTM D5185m	>200	3	2	1		
Tin	ppm	ASTM D5185m	>25	<1	0	<1		
Vanadium	ppm	ASTM D5185m		<1	0	0		
Cadmium	ppm	ASTM D5185m		<1	0	0		
ADDITIVES		method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		<1	0	0		
Barium	ppm	ASTM D5185m		<1	0	0		
Molybdenum	ppm	ASTM D5185m		<1	0	0		
Manganese	ppm	ASTM D5185m		0	0	<1		
Magnesium	ppm	ASTM D5185m	90	2	0	0		
Calcium	ppm	ASTM D5185m		<1	0	0		
Phosphorus	ppm	ASTM D5185m		12	6	17		
Zinc	ppm	ASTM D5185m		4	0	0		
CONTAMINANTS		method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>50	3	4	3		
Sodium	ppm	ASTM D5185m		<1	0	<1		
Potassium	ppm	ASTM D5185m	>20	1	0	<1		
Water	%	ASTM D6304	>0.2	0.002	0.023	0.007		
ppm Water	ppm	ASTM D6304	>2000	20	237.1	71.0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2		
Acid Number (AN)	mg KOH/g	ASTM D8045	0.25	0.54	0.524	0.50		
VISUAL		method	limit/base	current	history1	history2		
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE	NONE	▲ MODER		
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG		
Free Water	scalar	*Visual		NEG	n: MCHEAL RO	DAZNESOTBAL		





OIL ANALYSIS REPORT





FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	96.4	95.4	101
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						















Certificate 12367

Laboratory Sample No.

: RP0037809 Lab Number : 06156100

Unique Number : 10991523

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Apr 2024

Tested : 24 Apr 2024 Diagnosed : 24 Apr 2024 - Wes Davis

SOLVAY 1275 AIRLINE HWY BATON ROUGE, LA US 70805 Contact: MICHEAL ROJAS

micheal.rojas@solvay.com T: (225)573-3664

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: x: