


# **OIL ANALYSIS REPORT**

### Sample Rating Trend







# Machine Id CTC 3 Component Gearbox Fluid MORIL SHC 630 (--- Gr

## MOBIL SHC 630 (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

#### Wear

All component wear rates are normal.

#### Contamination

The water content is negligible. There is no indication of any contamination in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number	WATION	Client Info	mmoasc	RP0039506	BP0024248	BP0017307
Sample Number		Client Info		21 Apr 2024	05 May 2022	24 May 2021
Machine Age	hrs	Client Info		0 Apr 2024	05 May 2022	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1113	Client Info		N/A	N/A	N/A
Sample Status		Olletti IIIIO		NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<1	0	<1
Chromium	ppm	ASTM D5185m	>15	<1	0	0
Nickel	ppm		>15	<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	2	0	0
Lead	ppm	ASTM D5185m	>100	0	<1	0
Copper	ppm	ASTM D5185m	>200	<1	0	<1
Tin	ppm	ASTM D5185m	>25	<1	0	0
Antimony	ppm	ASTM D5185m	>5			0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		<1	0	2
Calcium	ppm	ASTM D5185m		<1	0	<1
Phosphorus	ppm	ASTM D5185m		394	367	384
Zinc .	ppm	ASTM D5185m		0	0	0
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	21	23	22
Sodium	ppm	ASTM D5185m		1	0	<1
Potassium	ppm	ASTM D5185m	>20	1	1	0
Water	%	ASTM D6304	>0.2	0.001	0.003	0.007
ppm Water	ppm	ASTM D6304	>2000	10	27.9	71.4
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
	1/011/	10711 00015			0.44	0.00=

Acid Number (AN)

mg KOH/g ASTM D8045


0.41


0.37

0.367




# **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	217.7	230	226	226
SAMPLE IMAGES	5	method	limit/base	current	history1	history2
Color						

**Bottom** 













Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : RP0039506 Lab Number : 06156105

Unique Number : 10991528

Received : 22 Apr 2024 **Tested** : 24 Apr 2024 Diagnosed

: 24 Apr 2024 - Wes Davis

US 02215 Contact: ROBERT ST SAUVEUR robert.stsauveur@engie.com T: (401)651-9381

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**ENGIE-MATEP** 

BOSTON, MA

474 BROOKLINE AVE