

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

SULLAIR 003-102440 MT OLIVE PICKLE

Compressor

PG-32 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sample Number Client Info WC0897677 WC0673419 UCSC	istory2
	732626
Sample Date Client Info 19 Apr 2024 26 Apr 2023 21 Oc	t 2022
Machine Age hrs Client Info 38859 32215 30657	7
Oil Age hrs Client Info 2000 2897 1341	
Oil Changed Client Info N/A Not Changd Not C	hangd
Sample Status NORMAL NORMAL NORMAL	ЛAL
CONTAMINATION method limit/base current history1 h	istory2
Water WC Method >0.1 NEG NEG NE	G
WEAR METALS method limit/base current history1 h	istory2
Iron ppm ASTM D5185m >50 1 <1 0	
Chromium ppm ASTM D5185m >10 <1	
Nickel ppm ASTM D5185m <1 <1 0	
Titanium ppm ASTM D5185m <1	
Silver ppm ASTM D5185m 0 <1 0	
Aluminum ppm ASTM D5185m >25 2 0 3	
Lead ppm ASTM D5185m >25 0 0	
Copper ppm ASTM D5185m >50 <1	
Tin ppm ASTM D5185m >15 <1 <1 <1	
Antimony ppm ASTM D5185m	
$\begin{tabular}{lllllllllllllllllllllllllllllllllll$	
Cadmium ppm ASTM D5185m <1	
ADDITIVES method limit/base current history1 h	istory2
Boron ppm ASTM D5185m 0 0	
Barium ppm ASTM D5185m 274 361 32	1
Molybdenum ppm ASTM D5185m <1 <1 0	
Manganese ppm ASTM D5185m 0 <1 <1	
MagnesiumppmASTM D5185m250	
Calcium ppm ASTM D5185m 3 <1	
Phosphorus ppm ASTM D5185m 11 5 11	
Zinc ppm ASTM D5185m 4 0	
Sulfur ppm ASTM D5185m 509 487 395	3
CONTAMINANTS method limit/base current history1 h	istory2
Silicon ppm ASTM D5185m >25 2 1 <1	
Silicon ppm ASTM D5185m >25 2 1 <1	
pp	

Acid Number (AN)

mg KOH/g ASTM D8045


0.08


0.272

0.08



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID FROFE	N I IES	memou		HISTOLAL	HISTOLA
Visc @ 40°C	cSt	ASTM D445	44.4	41.8	41.3


SAMPLE IMAGES m	nethod l			history1	history2
-----------------	----------	--	--	----------	----------















Certificate 12367

Laboratory Sample No.

Lab Number : 06156126 Unique Number : 10991549

: WC0897677

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Apr 2024 **Tested** : 23 Apr 2024

Diagnosed : 24 Apr 2024 - Sean Felton

203 AERO COURT GREENSBORO, NC US 27409

Contact: Dallas Burcham dallas.burcham@fs-compression.com

T: (336)605-9622 F: (336)605-9844

FS-COMPRESSION CO, LLC

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AIRGREWC [WUSCAR] 06156126 (Generated: 04/24/2024 13:52:01) Rev: 1