

## **OIL ANALYSIS REPORT**

Sample Rating Trend



### Area **S46** [284564] **PNEUTECH AK100017019 - AVA** Component

Component Compressor

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>/IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001595		
Sample Date		Client Info		02 Apr 2024		
Machine Age	hrs	Client Info		1556		
Oil Age	hrs	Client Info		1326		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	4		
Tin	ppm	ASTM D5185m	>15	2		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		<1		
Phosphorus	ppm	ASTM D5185m		367		
Zinc	ppm	ASTM D5185m		12		
Sulfur	ppm	ASTM D5185m		1305		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.52		



(J-046 (J-046 44 42 40 Abnorma

> 38 Apr2/24

# **OIL ANALYSIS REPORT**

Acid Number 0.60 (B/H0.41 뤁 0.36 aq u 0.24 Pio 0.12 0.00 Apr2/24 -Anr2/74 Viscosity @ 40°C 52 Abnormal 50 48

	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Apr2/24	Appearance	scalar	*Visual	NORML	NORML		
Ap	Odor	scalar	*Visual	NORML	NORML		
С	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	IES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		47.4		
	SAMPLE IMAGES		method	limit/base		history1	history2
Api2/24 +	Color					no image	no image
	Bottom					no image	no image
	iron chromium nickel chromium nickel			Apr2/24			
	Non-ferrous Metals	5		Apr224			
	Viscosity @ 40°C			.0 .0 H(d) .0 Winnber .0 Acid	Acid Number		
	Apr2/24			Apr2/24	Apr2/24		Apr2/24 +
Laboratory Sample No. Lab Number Unique Number Test Package To discuss this sample report, * - Denotes test methods that Statements of conformity to sp	: 10991552 : IND 2 contact Customer Servi are outside of the ISO 12	Rece Teste Diagi ce at 1-8 7025 sco	ean Felton	FLUID-AIRE DYNAMICS - (MN) 14250 JUDICIAL ROAD BURNSVILLE, MN US 55306 Contact: Service Manager T: 106:2012) F:			

Report Id: UCFLUBUR [WUSCAR] 06156129 (Generated: 04/24/2024 13:57:25) Rev: 1

Contact/Location: Service Manager - UCFLUBUR