


OIL ANALYSIS REPORT

OIL ANAL 1313 NEPON

FSC-8000 FS CURTIS NV22M22067 - SIMCOR

Component Compressor



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|------------------|----------|-------------|------------|-------------|-------------|----------|
| Sample Number | | Client Info | | UCH06156154 | UCH05975929 | |
| Sample Date | | Client Info | | 29 Feb 2024 | 08 Sep 2023 | |
| Machine Age | hrs | Client Info | | 6174 | 2967 | |
| Oil Age | hrs | Client Info | | 6174 | 2967 | |
| Oil Changed | | Client Info | | Not Changd | Not Changd | |
| Sample Status | | | | NORMAL | NORMAL | |
| CONTAMINATION | ٧ | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | NEG | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | <1 | <1 | |
| Chromium | ppm | ASTM D5185m | >10 | <1 | 0 | |
| Nickel | ppm | ASTM D5185m | | <1 | 0 | |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | |
| Silver | ppm | ASTM D5185m | | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >25 | 2 | 0 | |
| Lead | ppm | ASTM D5185m | >25 | 0 | 0 | |
| Copper | ppm | ASTM D5185m | >50 | 5 | 2 | |
| Tin | ppm | ASTM D5185m | >15 | <1 | 0 | |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | |
| Cadmium | ppm | ASTM D5185m | | <1 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | |
| Barium | ppm | ASTM D5185m | 20 | <1 | 0 | |
| Molybdenum | ppm | ASTM D5185m | | <1 | 0 | |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | |
| Magnesium | ppm | ASTM D5185m | | <1 | 0 | |
| Calcium | ppm | ASTM D5185m | 20 | <1 | 0 | |
| Phosphorus | ppm | ASTM D5185m | 320 | 6 | 3 | |
| Zinc | ppm | ASTM D5185m | 20 | <1 | 0 | |
| Sulfur | ppm | ASTM D5185m | 3000 | 3921 | 2904 | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 18 | 13 | |
| Sodium | ppm | ASTM D5185m | | 1 | 0 | |
| Potassium | ppm | ASTM D5185m | >20 | 1 | 0 | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.14 | 0.081 | 0.057 | |




OIL ANALYSIS REPORT










₹ 45 40







Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06156154

: UCH06156154 Unique Number : 10991577

Received : 22 Apr 2024 **Tested** : 23 Apr 2024 Diagnosed

: 24 Apr 2024 - Sean Felton

TATE ENGINEERING

150 EARLAND DR, BUILDING 5 NEW HOLLAND, PA US 17557

> Contact: BRIAN CODER brian.coder@tate.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: BRIAN CODER - UCTATNEW

T: F: