




OIL ANALYSIS REPORT

Machine Id
Grand Blanc CAT 5 GBLM05BE
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

Sample Rating Trend



DEGRADATION



DIAGNOSIS

▲ Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. (Customer Sample Comment: 800hr oil sample)

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

▲ Fluid Condition

The BN level is low. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0905670	WC0905696	WC0905746
Sample Date	Client Info		18 Apr 2024	10 Apr 2024	03 Apr 2024
Machine Age	hrs	Client Info	60027	59838	59646
Oil Age	hrs	Client Info	782	0	0
Oil Changed	Client Info		Not Chngd	N/A	N/A
Sample Status			SEVERE	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>.11	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	4	4	2
Chromium	ppm	ASTM D5185m >4	<1	<1	0
Nickel	ppm	ASTM D5185m	0	1	0
Titanium	ppm	ASTM D5185m	0	<1	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >6	2	2	2
Lead	ppm	ASTM D5185m >9	3	4	0
Copper	ppm	ASTM D5185m >6	3	2	<1
Tin	ppm	ASTM D5185m >4	2	3	<1
Vanadium	ppm	ASTM D5185m	0	<1	<1
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	5	6
Barium	ppm	ASTM D5185m	1	0	0
Molybdenum	ppm	ASTM D5185m	3	4	2
Manganese	ppm	ASTM D5185m	1	1	0
Magnesium	ppm	ASTM D5185m	15	11	10
Calcium	ppm	ASTM D5185m	2041	1912	1846
Phosphorus	ppm	ASTM D5185m	306	309	250
Zinc	ppm	ASTM D5185m	388	365	343
Sulfur	ppm	ASTM D5185m	3894	3553	3328

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >181	161	130	99
Sodium	ppm	ASTM D5185m >21	2	0	<1
Potassium	ppm	ASTM D5185m >20	0	3	0

INFRA-RED





	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	6.3	6.3	5.8
Sulfation	Abs/.1mm	*ASTM D7415	25.9	24.7	22.6

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	17.6	16.7	14.4
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	2.53	▲ 2.11	1.70
Base Number (BN)	mg KOH/g	ASTM D2896 5.4	▲ 2.19	2.36	2.69











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.9	13.8

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0905670
Lab Number : 06156192
Unique Number : 10991615
Test Package : MOB 2
Received : 22 Apr 2024
Tested : 23 Apr 2024
Diagnosed : 24 Apr 2024 - Sean Felton

EDL NA Recips-Grand Blanc
 Grand Blanc Powerstation, 2361 West Grand Blanc Road
 Grand Blanc, MI
 US 48439
 Contact: Tony Saint Marie
 tony.saintmarie@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)