

# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 6208390**

## Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- QTS)

### DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

# Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013704	KCPA007844	
Sample Date		Client Info		22 Apr 2024	18 Oct 2023	
Machine Age	hrs	Client Info		34181	31368	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	3	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	2	6	
Tin	ppm	ASTM D5185m	>10	1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	89	36	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	83	64	
Calcium	ppm	ASTM D5185m	0	0	1	
Phosphorus	ppm	ASTM D5185m	0	5	<1	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	20089	20617	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	
Sodium	ppm	ASTM D5185m		35	14	
Potassium	ppm	ASTM D5185m	>20	10	3	
Water	%	ASTM D6304	>0.05	0.025	0.027	
ppm Water	ppm	ASTM D6304	>500	250	274.2	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		18986	3870	
Particles >6µm		ASTM D7647	>1300	<u> </u>	579	
Particles >14µm		ASTM D7647	>80	<b>A</b> 339	29	
Particles >21µm		ASTM D7647	>20	<mark>/</mark> 91	6	
Particles >38µm		ASTM D7647	>4	3	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 21/19/16	19/16/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.38	0.43	

Contact/Location: Service Manager - AMAFRE Page 1 of 2





Built for a lifetime

# **OIL ANALYSIS REPORT**









Lab Number Unique Number : 10992350 Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Laboratory

Sample No.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AMAFRE [WUSCAR] 06156927 (Generated: 04/24/2024 17:41:38) Rev: 1

Contact/Location: Service Manager - AMAFRE

T:

F:

Contact: Service Manager

favjazmi@amazon.com